# Faro Mine Complex Water Management Infrastructure Inventory

PREPARED FOR: Government of Yukon

PREPARED BY: CH2M HILL Canada Limited

DATE: August 27, 2014

PROJECT NUMBER: 472645.17.CM.01

# **Purpose**

The purpose of this memorandum is to present the Government of Yukon (YG) with a description and explanation of Table 1 (attached), which will be instrumental to the Water Management Infrastructure Inventory (WMII) at the Faro Mine Complex (FMC).

## **Background**

While developing the GoldSim model for the FMC, it became clear to CH2M HILL Canada Limited (CH2M HILL) that a complete inventory of the site's pumping systems would be required to create an accurate hydraulic model. According to the Standing Offer Agreement and, more specifically, under Task Authorization (TA) 17, CH2M HILL was tasked with assembling this data and presenting it to YG. CH2M HILL will also use this data to complete risk assessments, plan future upgrade projects, and assist with critical spare parts identification.

## **Table Description and Explanation**


Table 1 is first broken down by Area at the FMC, and then by type of water conveyance system. This table and the attached Piping and Instrumentation Diagrams (P&IDs) are living documents. CH2M HILL recommends they be updated as new information becomes available. CH2M HILL also recommends that more accurate and complete P&IDs be developed for each conveyance system onsite based on the limitations described below.

#### Limitations

The information in Table 1 and on the P&IDs has not been field verified and its accuracy has not been independently checked. The majority of this information has been gathered from personnel onsite, and not via direct engineering measurements. A large portion of this information was provided by the site Water Treatment Specialist, Dan Duivenvoorden, who has been working at the FMC for many years. CH2M HILL interviewed Dan to gather information that only he can provide, and compiled it in a document that YG, as well as the Design Team, can readily access.

Note: Table 1 is not complete. There is still a large amount of data to collect, which will not be available until summer 2014 when each conveyance system can be evaluated in detail and filed-verified. As mentioned, a list of critical spare parts must also be developed. Table 1 will be updated to include more photographs, specifications, and supporting documents as they become available.

ES102011123831RDD



#### Faro Mine Complex Water Management Infrastructure Inventory

Faro Mine Remediation Project

Area	System	System	Frequency and Period o	of Typical Range of Fluid Characteristics (PH, Temp, TSS)	Pump Housing or Supporting Structure	Intake Location & Elevation (masl)	Discharge Location & Elevation	Pumps (& elevation)	Serial / Model #'s	Motor (VFD or constant) HP, Manufacturer, Model #	Flange Size		Piŗ		Piping *		System Flow	Reducers, elbows,	Instruments (pressure gauges,	Valves	Critical	Relevant Pictures, Figu
		oyote	use								Inlet	Discharge	ID	OD	SDR	Length	Capacity **	fittings	flow meters)	(serial #'s)		and Diagrar
wn Valley	X5 Siphon		Used when needed.	PH: 7.11 - 8.20	Intake floats	Min: 1026.307							-	10"	Variable	1000'	7,000 L/min					
			Maximum draw down of	Temperature: Avg = 8.33 C		Max: 1020.329	-	-	-	-	-	-	13.812	16"	15.5	1000'	20,000 L/min					
			10cm.	Total Suspended Solids: Avg=2 mg/L		Avg: 1028.384																
	IP to Faro	IP to Tailing Pump House	Typically April to	PH: 3.06 - 7.56	A barge supports the pumps and a seaman	Min: 1042.959	Pumps are on water surface	Two vertical turbine	9TLE 2100	Electric, variable frequency		10"	8.219"	10"	9	100'	8,200 L/min					<b>T</b>
			October	Temperature: Avg= 5.17 C	houses the MCC, instrument and surge	Max: 1047.575	and assumed to be	electric Robco pumps	16/17	drive			10.701"	14"	9	300m						
				Total Suspended Solids: Avg=10 mg/L	protection.	Avg: 1045.993	discharging at same height				-		11.301"	14"	11.5	900m						
													12.882"	14"	15.5	1500m						
		ETA to Tailings Pump	Typically April to	PH: 3.26 - 5.80	Large vertical concrete culvert. Pump	Information		Submersible electric		Electric, continuous drive.	-	4"	ł	8"	Variable	1,500'	1,000 L/min					+
			October	Temperature: Avg = 5.06 C	suspends from a come-along into the	forthcoming		Flygt pump		30HP, 575V	_	ľ		Ů	Variable	1,500	1,000 L/111111					
		liouse	October	Total Suspended Solids: Avg=213 mg/L	culvert.	Torthcoming		i iyac pump		30111, 3734												
		Tailings Pump House to	Typically April to	Not available	125m3 sump tank inside the tailings pump	Information		Miller Skid Pump	SC86C17-	Electric, variable frequency	8"	6"	18.346"	24"	9	4,200'	3,000 USG/min					1
			October		house. New Miller Skid Pump comes with	forthcoming			HO.	drive. 200HP, 575V	_		12.086"	14"	15.5	100'	-,					
					its own tank				CD4MCV					ļ								
	S- Wells		Continuous	PH: 6.34 - 7.30	Seacan is sitting over a collection sump.	Min:		Submersible electric		Electric, variable frequency		3"		2"		5,000'	2.9 L/sec					1
				Temperature: Avg = 5.09 C	Heat trace is now installed	Max:		Grundfos pump		drive. 15HP				4"		'	7 L/sec					
				Total Suspended Solids: Avg=23 mg/L		Avg:					_						(combined)					
	Zone 2		Continuous	PH: 6.59 - 7.08	Seacan is above the well and houses the	Min: 1097.924		Submersible electric		15HP		3"		3"		1,500'	5 L/sec	1				+
	20.10 2		Continuous	Temperature: Avg = 5.66 C	instrumentation	Max: 1113.301		Grundfos pump		23	_					2,500	5 2, 500					
				Total Suspended Solids: Avg=15 mg/L		Avg: 1106.048																
ngorda &	Grum Pit to Va	angorda Pit	Typically April to	PH: 7.75 - 8.38	A small barge will support the pump.	Min: 1203.198	Pumps are on water surface	Submersible electric		Electric, soft start, fixed speed.		6"	10.453	16"	6.3	500m	50 L/sec					
rum			October	Temperature: Avg=5.07 C		Max: 1186.658	and assumed to be	Sulzer pump		140HP 575V	-		11.441	16"	7.3	320m						
				Total Suspended Solids: Avg= 6 mg/L		Avg: 1216.816	discharging at same height						11.919	12"	32.5	2,200m						
	Vangorda Pit	Pit to Booster	Typically June to	PH: 3.07 - 7.43	A barge supports the pump. A walkway	Min: 1074.584	Pumps are on water surface	Vertical turbine electric	14 JHE	Electric, soft start, fixed speed.		10"	11.353	16"	7.3	1100m	8,500 L/min					
	to WTP		September	Temperature: Avg = 6.14 C	runs from the barge to a float, and another	Max: 1094.085	and assumed to be	Robco pump		350HP 4160V		(150 Psi										
				Total Suspended Solids: Avg=12 mg/L	walkway runs from the float to the shore	Avg: 1085.167	discharging at same height					30' Flex hose)										
		Booster to Water	Typically June to	PH: 3.07 - 7.43	A small hut with a roof and two walls is		Same as the intake	Vertical turbine electric	14 IHE	Electric, soft start, fixed speed.		10"	10.615"	16"	6.3	1,100m	8,500 L/min	+				+
			September	Temperature: Avg = 6.14 C	built over the pump. A large "sump can" is		elevation.	Robco pump	143116	350HP 4160V		(300Psi)	12.231"	16"	9	150m	0,500 L/11111					
		Treatment Flant	September	Total Suspended Solids: Avg=12 mg/L	used to gather the water from the first		cicvationi	nosco pamp		330111 11001	-	(500.51)	12.915"	16"	11	270m						
					pump, and boost it to the plant								12.086"	14"	15.5	1,240m						
	GSC Lined Pon	nd	Typically April to	Not available	Suction hose	Min: 1081.416		Diesel Godwin pump	HL6M	Constant drive, Cat N7 motor	8"	6" (High pressure		8"	17	1,200'	4,000 L/min					
			October			Max: 1189.659				·		LayFlat)										
						Avg: 1182.985																
	GSC Un-Lined	Pond	April to July	PH: 7.31 - 8.30	Suction hose	Min: 1165.361		Rental pump required						10"	32.5	1,000'						
				Temperature: Avg = 8.33 C		Max: 1189.086																
				Total Suspended Solids: Avg=2 mg/L		Avg: 1167.367																
	V-15		Excessive flows are	PH: 7.31 - 8.30	Seacan is above a 22' gravity fed culvert for	-		Vertical turbine electric		Electric, variable frequency		3"		3"		3,000'	9 L/sec					
			pumped from April to	Temperature: Avg = 3.75 C	collection and pumping			Grundfos pump		drive. Uncommissioned. 15HP	-											
			June	Total Suspended Solids: Avg=3 mg/L						575V			<u> </u>	611		2 222	1	<b>_</b>				
	Little Creek Da		Typically April to	PH: 2.82 - 6.90	Small float	Min: 1106.484	Pumps are on water surface			Electric, constant drive. 30HP		4"		6"	Variable	2,000'						
			October	Temperature: Avg = 10.79 C		Max: 1111696	and assumed to be	Flygt pump		575V	-											
	Surimming !!=!	la.	Tunically April to	Total Suspended Solids: Avg=19 mg/L	A frame support system for the sure-	Avg: 1108.864	discharging at same height	Cubmarcible alact-i-		Electric constant drive 15110		4"	<u> </u>	6"	Variable	300'	Unknown	<del>                                     </del>				+
	Swimming Hol	ile	Typically April to October	Not available	A frame support system for the pump			Submersible electric Flygt pump		Electric, constant drive. 15HP 575V	-	4		0	Variable	300	Unknown					
	Groucho Pond	1	June to September	Not available	Vertical culvert in the pond			Gallagher sump pump		Electric, constant drive. 20HP	<del>                                     </del>	4"	l	3"	Variable	700'	Unknown	<del>                                     </del>		<del>                                     </del>	1	+
	5. 540.10 i oliu	-	and to september					Tanagarer samp pamp		575V	-			Ĭ	- anabic	1						
	Dredging Line	***	Depends on discharge	Not available	A frame support on a donut shaped float.			Submersible electric		Electric, constant drive. 75HP		6"		8"	17	120'	5,000 L/min					
			requirements		Winches also used to raise and lower the			Toyo pump	İ	575V	-											
	1				pump																I	1


\* All lengths are approximate


\* All flows are approximate and will require verification.

\*\*\* The dredging line uses the same infrastructure as the "Booster to Water Treatment Plant" system, in reverse. It then pours into the Vangorda Pit

\*\*\*\* Hidden cells reserved for new piping system to deliver water to and from the Interim Water Treatment Plant

All information in this table is preliminary, and will need to be field verified.






Temperature: Avg = 5.66 C


Total Suspended Solids: Avg=15 mg/L


CH2MHILL.

Grundfos pump

© CH2M HILL







### NOTE: PRELIMINARY INFORMATION IN THE TABLE TO BE FIELD VERIFIED

				F	Piping Data							
Area	System	Pumps	Pumps Serial / Model #'s		Typical Operating Flow Discharge (L/min) (inches)		Pipe dia (inches)	МОС	SDR	Length (meters)	Typical Fluid Data (pH, Temp, TSS)	
Down Valley	X5 Siphon	-	-	7000 L/min 20000 L/min	-		10 16	HDPE	Variable 15.5	305	PH: 7.11 - 8.20 Temperature: Avg = 8.33 C Total Suspended Solids: Avg=2 mg/L	

# NOTES:

1. PRELIMINARY DRAWING, INFORMATION TO BE FIELD VERIFIED.

DOWN VALLEY-X5 SIPHON SYSTEM

472645-PS-004

CH2MHILL.