CHILKOOT GEOLOGICAL ENGINEERS LTD.

Box 31146, Whitehorse, Yukon Y1A 5P7 chilkoot@northwestel.net (867) 335-2085 c

Geotechnical Evaluation and Limited Phase II Environmental Site Assessment Lot 2, Block HB, Haper Estate (8338A CLSR) Dawson City, Yukon – 2015



Prepared For: Date : Project No: Yukon Government – Energy, Mines & Resources September 8, 2015 200-006-15

# **TABLE OF CONTENTS**

# Geotechnical Evaluation and

# Limited Phase II Environmental Site Assessment

# Lot 2, Block HB, Haper Estate (8338A CLSR)

# Dawson City, Yukon - 2015

SEC	TION		PAGE
1.0	INT	RODUCTION	1
2.0	ME	THODOLOGY	2
	2.1	Literature Review	2
	2.2	Field Work Program	3
	2.3	Laboratory Work Program	7
3.0	SITI	E CONDITIONS	8
	3.1	General	8
	3.2	Legal Description and Site Location	8
	3.3	Site Description	9
	3.4	Geomorphology	9
	3.5	Surficial Geology	10
	3.6	Bedrock Geology	10
	3.7	Subsurface Conditions	10
4.0	DIS	CUSSIONS	14
5.0	ENV	<b>VIRONMENTAL RECOMMENDATIONS</b>	15
6.0	GEC	DTECHNICAL RECOMMENDATIONS	16
	6.1	Foundations	16
	6.2	Allowable Bearing Pressure	16
	6.3	Differential Movements	17
	6.4	Deleterious Materials	17
	6.5	Excavations	17
	6.6	Excavation Parameters	18
	6.7	Granular Pad	19
	6.8	Filter Fabric	21

# **TABLE OF CONTENTS**

# Geotechnical Evaluation and Limited Phase II Environmental Site Assessment Lot 2, Block HB, Haper Estate (8338A CLSR) Dawson City, Yukon – 2015

<b>SEC</b>	TION		PAGE
	6.9	Structural Breaks & Reinforcing	21
	6.10	Site Drainage	22
	6.11	Inclement Weather	22
	6.12	Temporary Excavations & Worker Safety	22
	6.13	Surface and Groundwater	23
	6.14	Temporary Stockpiles	24
	6.15	Sub-surface Utilities	24
	6.16	Driveways and Parking Areas	25
	6.17	<b>Construction Monitoring and Testing</b>	26
	6.18	Foundation Monitoring	26
7.0	CON	ICLUSIONS	27
8.0	LIM	ITATIONS	28
9.0	CLO	SURE	30
		APPENDICES	

FIGURE 1	-	Site Location
FIGURE 2	-	Borehole Locations
APPENDIX A	-	Soil Logs
APPENDIX B	-	Results of Grain Size Distribution Analysis
APPENDIX C	-	<b>Results of Analytical Analysis</b>
APPENDIX D	-	Specifications for Imported Fill
APPENDIX E	-	Selection of Photos

# **1.0 INTRODUCTION**

*Chilkoot Geological Engineers Ltd.* was retained by *Yukon Government (YG) -Energy Mines and Resources* to conduct a Geotechnical Evaluation at Lot 2, Block HB located in the Haper Estate Stewart Menzies Subdivision in Dawson, Yukon. In addition, as our firm identified a potential environmental concern during the Phase I Environmental Site Assessment for the property, a sampling program was conducted to characterize the site in greater detail.

Specifically, the environmental concern was associated with the sites proximity to a former *White Pass* site. The *White Pass* company was commonly associated with poor environmental practices and fuel distribution.

The purpose of the evaluation was to determine the subsurface conditions at the proposed subject property and provide geotechnical recommendations regarding residential foundation construction for an envisioned cribbing and ventilated crawlspace foundation system. The purpose of the limited Phase II ESA was to obtain a soil and water sample to allow for analytical analysis relative to potential hydrocarbon contaminants.

Authorization to proceed was granted on July 31<sup>st</sup>, 2015 by *YG* - *Energy, Mines and Resources* - *Lands Management Branch* - *Lands Availability Manager,* Mr.R.Gorczyca. The field work was conducted on August 8<sup>th</sup>, 2015 in accordance with our July 16<sup>th</sup>, 2015 proposal.

A detailed description of our methodology and geotechnical recommendations which will allow for residential building construction have been provided below

# 2.0 METHODOLOGY

Our work methodology was comprised of a literature review as well as a field and laboratory work programs.

# 2.1 Literature Review

A literature review was conducted prior to the field work program to better evaluate the regional conditions. The following sources of information were reviewed;

#### Surficial Geology Map

A 1:250,000 surficial geology map (*YT*, *File 3288*) compiled by *A.Duk-Rodkin*, *1996*, was reviewed to assess the regional soil conditions.

In brief, the map described the area as being comprised of fluvial deposits.

#### Bedrock Geology Map

The following bedrock geology maps were reviewed through the *Yukon Geological Survey* website;

Geology, Ogilvie, Map 711A, by H.Bostock, 1942Scale 1:253,440Bedrock Geology, YT, G.S.C. Open File 3754, 2001Scale 1:1,000,000

The maps suggest that Dawson is underlain mainly by green schist to lower amphibolite facis metamorphic rocks of the Yukon-Tanana Terrane.

# 2.2 Field Work Program

The field work program was comprised of a site reconnaissance, utility locates and drilling program.

# Site Reconnaissance

A site reconnaissance was previously conducted during the Phase I ESA to note the field conditions at the subject property on July  $1^{st}$ , 2015 Our observations have been presented in Section 3.3 – Site Description, below.

# **Utility Locates**

*Northwestel, Yukon Energy Corporation* and the *City of Dawson* were contacted prior to conducting the drilling program in order to verify that the region was clear of potential underground hazards.

While phone and power-lines were located overhead nearby, there were local subsurface sewer and water lines (and stubs) located along the adjacent avenue. Otherwise the proposed borehole locations were free of underground utilities.

# **Drilling Program**

The drilling program was conducted on August 8<sup>th</sup>, 2015 *Donjek Services* utilizing a CME-750 drill mounted on an FN-60 Nodwell.

The program was comprised of advancing two boreholes in order to obtain soil samples and characterize the subsurface conditions. The first borehole (BH 1-15) was advanced utilizing 150 mm  $\emptyset$  solid-stem continuous flight augers. The second borehole (BH 2-15) was advanced utilizing 200 mm  $\emptyset$  hollow-stem augers to allow for sampling through Standard Penetration Testing (SPT) and subsequent installation of a 2"  $\emptyset$  monitoring well.

The boreholes were advanced to depths of 4.27 and 4.41 respectively.

#### Borehole Locations & Survey

Following completion of the drilling, the elevation of the boreholes were surveyed relative to the adjacent alleyway, utilizing a (*Leica LR Rugby*) laser level. The ground surface at the location of the monitoring well (at BH 2-15) was given an arbitrary elevation of 100.00 meters. The elevation of the boreholes have been noted on the Soil Log enclosed in Appendix A. The spot elevations taken on the adjacent roadways was noted to be in the order of 0.3 to 0.5 meters higher in elevation than those of the prevailing grades.

The location of the boreholes were measured relative to prominent reference points and have been plotted on Figure 2.

#### Soil Log

During drilling, field soil logs were maintained by the undersigned. This information was utilized to compile the Borehole Soil Logs which have been enclosed in Appendix A. The appendix also includes '*Notes on Soil Classification*' the 'Unified Soil Classification System' and the 'Classification for Frozen Soils (adapted by Linnell and Kaplar, 1966)', for reference purposes.

In brief, the Borehole Soil Logs were compiled utilizing a combination of field logs, visual observations and results of the laboratory analysis.

#### Sampling Program

A total of ten (10) soil samples were retained during drilling operations.

The soil samples were retained at regular intervals during the solid-stem drilling by obtaining grab samples directly from the auger flighting or else from the split-spoon sampler tube where the hollow-stem augers were advanced.

Once the soil samples were retained, they were described on the field soil logs. The soil samples were then sealed in air-tight plastic bags and numbered consecutively in order to allow for laboratory analysis.

In addition to the drilling samples, a single soil sample was obtained from a local low spot (noted in Figure 2) through hand sampling techniques. The sample was retained from soils located directly below a 0.1 meter thick organic mat which was encountered at this location.

The samples were subsequently transported to *Chilkoot Geological Engineers Ltd.*'s Whitehorse laboratory facilities to undergo more detailed examination and analysis described in *Section 2.3*, below.

#### Monitoring Well Installation

A 2" diameter ABS monitoring well was installed to a depth of approximately 4.41 meters below the existing ground surface to allow for future monitoring of the local groundwater conditions.

The lower 1.5 meters of the well was slotted and the annular space was backfilled with imported filter sand. The exception to this were 0.3 meter thick zones (located 0.3 meters above the slotted portions of the pipe and 0.6 meters below the ground surface) where a bentonite plug was installed to seal the annular space in accordance with good installation practices. Access to the

6

well was restricted through the installation of a 4 inch diameter locked steel casing which was concreted into the ground surface.

#### **Borehole Termination**

Following drilling the borehole was left undisturbed for approximately 15 minutes to assess the sidewall stability (solid-stem borehole) and better assess groundwater conditions. In brief, the excavation sidewalls in the solid-stem borehole was noted to collapse to a depth of 2.44 meters below the ground surface.

Refusal was not encountered during the drilling.

#### Backfill

Following our observations, the boreholes were backfilled utilizing the auger cuttings. Bentonite pellets were placed at the zones noted in 'Monitoring Well Installation' section above, in accordance with good drilling practices to separate potential hydrological zones.

# Photographs

Photos were taken during the work to document the field work program, laboratory soils samples and site conditions. A selection of these photos has been provided in Appendix E.

# 2.3 Laboratory Work Program

The laboratory work program was comprised of both physical and analytical analysis.

#### 2.3.1 Physical Laboratory Analysis

A physical laboratory work program was conducted in order to characterize the index properties and conditions of the retained soil samples.

The analysis was conducted between August  $12^{th}$  and  $14^{th}$ , 2015 at our Whitehorse laboratory facilities. In brief, the analysis was comprised of natural moisture content determination and visual laboratory classification of all ten (10) retained soil samples. The moisture content analysis was conducted in accordance with ASTM D 2216-92. The results of the analysis have been denoted as 'MC' ( $\odot$  - Symbol) on the Soil Logs enclosed in Appendix A.

Grain size distribution analysis was also conducted on, two (2) of the samples (in accordance with ASTM D 422-633) in order to classify the soil utilizing the *Unified Soils Classification System*. The results of the analysis have been summarized on the Soil Logs enclosed in Appendix A with the percent composition of fines (silt & clay), sand and gravel denoted with the symbols -  $\triangle$ ,  $\bigcirc$  &  $\blacksquare$  respectively. The results of the individual grain size distribution analysis have been presented in Appendix B.

#### 2.3.2 Analytical Laboratory Analysis

An analytical laboratory work program was conducted in order to characterize the levels of hydrocarbon contaminants in a soil and water sample retained during the field work program. In addition, the water sample was analyzed to determine its metals content.

The analysis was conducted between August  $13^{th}$  and  $19^{th}$ , 2015 at our laboratory sub-consultants *EXOVA*'s laboratory facilities. The results of the analytical analysis have been enclosed in Appendix C.

In brief, the result of the soil analysis indicated heavy extractable petroleum hydrocarbon (HEPH) levels of 1140 ppm. These readings exceed the allowable corresponding *YG* - *Contaminated Site Regulation* residential standards of 1000 ppm.

# 3.0 SITE CONDITIONS

# 3.1 General

The subject property is comprised of historically disturbed/ disturbed/ developed/ developed land which is currently vacant. The lot was however vegetated with trees and willow bush.

# **3.2 Legal Description and Site Location**

The legal description of the subject property is;

Lot 2, Block HB, Haper Estate (8338A CLSR)

The subject property is located in Dawson, Yukon, as noted in Figure 1.

The subject property (a.k.a. 'site') is approximately  $0.046 \pm ha$  in size and is rectangular in shape (50' by 100'.

Access to the site is via  $2^{nd}$  Avenue which lies to the north and a back alley.

# 3.3 Site Description

Regionally, the subject property is located on the banks of the Yukon River and so very little relief in elevation is noted within the townsite.

Local site development and residential construction is occurring on a number of nearby properties. The work appears to be comprised of placement of clean granular backfill upon which cribbing and residential houses are being constructed.

The subject property is currently comprised of undeveloped land which is moderately vegetated. It's apparent that people have traversed the site as evidenced by miscellaneous incidental debris such as the odd pop can, plastic bag, etc.

# 3.4 Geomorphology

# Glaciation

Although the full extent of the earliest glaciation is unknown, evidence shows that the Dawson area and Klondike Plateau have probably never been glaciated.

# Natural Hazards

The following natural hazards may be regionally present;

# Floods

As with the majority of Dawson, the site would be prone to flood events if it were not for the protective dike which was established in the 1980's. The site would likely have been previously flooded prior to the establishment of the dike.

#### 3.5 Surficial Geology

The deposits noted in the Dawson area are comprised of Klondike River Valley Deposits. These deposits are characterized by organics/peat which overlie fine grained fluvial materials ranging from sands to silts with minor amounts of gravel. These materials overlie predominately coarse grained materials (where the tailings are derived). Based upon the undersigned's past experience in the Dawson area, it is anticipated that these soils are clean and contain high percentages of cobble to boulder sized materials.

Due to the poor founding nature of the soils located in the Dawson area, considerable amounts of fill have been imported to facilitate both historical and more recent development. The historical fills overlie the above noted native deposits and are typically medium to coarse grained but contain an appreciable amount of fines and deleterious (organic) materials.

#### 3.6 Bedrock Geology

In brief, the geology maps suggest that Dawson is underlain mainly by green schist to lower amphibolite facis metamorphic rocks of the Yukon-Tanana Terrane. While the depth to bedrock in the low lying valley regions will vary, it is understood that it is typically encountered at depths of 20 to 30 meters in the region of the townsite.

#### 3.7 Subsurface Conditions

#### Soil Stratigraphy

Detailed descriptions of the soil stratigraphy that was encountered have been provided on the Borehole Soil Logs attached in Appendix A.

In general, the subsurface soil units which are typically encountered in Dawson can be classified as;

#### **Unit** # 1 – **Fill**;

which are medium to coarse grained and contain an appreciable amount of fines and potential organics, overlying;

#### Unit # 2 – Peat/Organic Stratum;

which are wet and rich in organics, overlying;

This unit was notably absent at the locations where the boreholes were advanced and may have been removed during previous site development.

# Unit # 3 – Alluvial Channel Deposits;

which are predominately silty in nature, but may contain finer clay sized materials and/or coarser interbedded granular materials, overlying;

# Unit # 4 – Alluvial Valley Deposits;

which are predominately clean, coarse grained and contain cobble and possibly boulder sized materials.

A detailed description of the soil units encountered during our firm's field work program has been provided below.

#### **Unit** # 1 – Fill;

The fill is comprised of predominately silty sand to sandy silt materials which contained varying amounts of fines and organics. The fill extended to a depth of approximately 1.2 meters below the existing ground surface. As with all undocumented fills, the fill may contain rubble, scrap steel, high levels of fines/organics and/or other deleterious materials.

A groundwater table was encountered within this soil unit in BH 2-15 at a depth of approximately 1.25 meters below the ground surface (at the borehole location).

#### Native Deposits

The native deposits are comprised of an organic stratum which overlies alluvial channel and valley deposits.

#### Unit # 2 – Peat/Organic Stratum;

The peat/organic stratum which typically underlies the fill in Dawson was notably absent at the borehole locations. However, as black organic inclusions were encountered in the upper realm of the Unit #3 materials, the stratum was likely present but may have been stripped (from this area) during historical lot development.

#### Unit # 3 – Alluvial Channel Deposits;

Alluvial channel deposits were encountered at a depth of 1.06 and 0.75 meters in BH 1-15 and BH 2-15, respectively.

The deposits were comprised of moist, non-plastic silt which contained varying amounts of clay, sand and gravel as well as organic inclusions and rootlets. The deposit was noted to grade coarser with depth to a silty and gravelly sand. Cobbles (and possibly boulder sized materials) may be encountered near the base of this soil unit. Conversely, given the nature of channel deposition, it may also contain regions of predominately organic deposits which are a result of channel infilling.

#### Unit # 4 – Alluvial Valley Deposits;

Alluvial valley deposits comprised of sandy gravel were encountered below the fine grained channel deposits at a depth of approximately 2.45 meters and 2.30 meters, in BH 1-15 and BH 2-15, respectively.

These soils were noted to be well washed, suggesting the presence of a fluctuating groundwater table. The groundwater table was encountered in each of these boreholes within this soil unit at a depth of approximately 3.4 to 3.5 meters

The boreholes were terminated within the soil unit at a depth of 4.27 and 4.41 meters, respectively.

#### Groundwater

The depth to groundwater was noted at 3.42 and 3.47 meters below the existing ground surface in BH 1-15 and BH 2-15, respectively.

Groundwater flow would likely be to the north-west, towards the Yukon River.

#### Seasonally Frozen Soils

While there was no indication of seasonally frozen soils, typically, the upper 1.8 to 2.0 meters of the soil column would be susceptible to seasonal frost. The depth of seasonal frost would depend upon the soil cover and types as well as climatic conditions.

#### **Permafrost**

Although there was no evidence of permafrost, Dawson lies within the zone of widespread discontinuous permafrost. The permafrost can vary from poorly bonded soils with non-visible ice to massive ice lenses ranging in size to tens of meters. Regionally the permafrost is probably more than 100 meters thick with taliks (thawed subsurface) present beneath large rivers (and lakes) and beneath south-facing slopes.

# Bedrock

There was no indication of bedrock within the boreholes which were advanced.

#### 4.0 DISCUSSIONS

The analytical results of the soil sample retained from the site noted hydrocarbon (HEPH) contaminants which exceeded the recommended soil criteria relative to residential standards.

The groundwater sample retained from the monitoring well however, did not show any signs of hydrocarbon contamination.

With the exception of the iron content, the metals analysis of the water sample retained from the monitoring well did not exceed any of the limits set forth by the YG – *Contaminated Site Regulations (CSR)*. The levels of iron exceeded the CSR criteria to protect against taste and odor concerns.

Following adequate site remediation, the existing subsurface conditions would allow for the construction of a granular pad upon which a residence could be supported on a PWF cribbing and ventilated crawlspace type of foundation system. Although thawed ground conditions were encountered, the construction of conventional footing or slab-on-grade foundation systems would not be recommended as regional fluctuations in the thermal and groundwater regime may affect the long-term performance of the structure.

#### 5.0 ENVIRONMENTAL RECOMMENDATIONS

As the retained soil sample exceeded the limits for hydrocarbon contamination, additional sampling should be conducted to better characterize its extent and other site locations. Given the existing tree cover, the characterization should be conducted by implementing a hand sampling program. The program sho

1 meter, in

anticipation that the contamination is limited to the near surface soils. If following the hand sampling program contamination is encountered to depths of 1 meter, clearing operations may be required to allow for drill rig access to obtain samples from greater depths.

Additional water samples should be retained to reconfirm the groundwater conditions.

Caution should be exercised during site remediation to ensure that backfill materials are comprised of clean, well-graded granular materials that are compacted to the required (80 mm minus) sub-base specifications contained within the recommendations provided herein within the limits of the building load envelope. Otherwise, poorly compacted backfill will become a liability during future site development.

#### 6.0 GEOTECHNICAL RECOMMENDATIONS

#### 6.1 Foundations

Standard residential building structures may be supported by PWF cribbing and ventilated crawlspace foundation system founded upon an approved granular base constructed in accordance with recommendations provided herein.

The PWF cribbing should be configured in such a way that the building structure can be intermittently re-levelled on an as needed basis.

The ventilated crawlspace should incorporate a sub-wall which skirts the buildings perimeter. The sub-wall should be comprised of wire mesh or lattice work such that air flow below the structure is unrestricted during the winter months. These openings should be configured in such a manner that they can be closed in the summer months to prevent (exterior warmer) air from flowing beneath the structure and impacting nearby permafrost. Ultimately, degradation of local or regional permafrost is not desirable and as such, efforts should be undertaken to protect the natural thermal regime.

#### 6.2 Allowable Bearing Pressure

The allowable bearing pressure should not be greater than 105 kilopascals for a cribbing and ventilated crawlspace foundation system constructed on the structural granular pad described herein.

This figure includes the total of all live and dead loads.

#### 6.3 Differential Movements

Differential movements in the order of (+/-) 25 mm may occur with the proposed foundation system. Periodic adjustment to the cribbing system should be anticipated throughout the life of the structure in order to accommodate the movements when these limits are exceeded or if gross settlement/heave occurs.

#### 6.4 Deleterious Materials

Following clearing and grubbing operations, the near surface organics should be removed and a level sub-grade surface should be prepared. The exposed sub-grade surface should be should be inspected by qualified geotechnical personnel to assess the suitability of the prepared surface on a case-by-case basis.

Subsequent preparation of a granular building pad should be conducted in accordance with Section 6.7.

Excavated soils which are frozen, have high moisture and/or organic contents should be hauled to waste as their use in non-structural applications will be limited.

#### 6.5 Excavations

Excavations should be conducted utilizing a tracked excavator equipped with a cleanup bucket in order to minimize disturbance to the sub-grade materials.

While excavation difficulties are not expected, hard digging will be encountered if/where frozen soils are encountered. If permafrost is exposed during excavation, it should be protected from degradation by implementing an accelerated work program,

utilizing insulated tarps and/or scheduling the project to such a time that thermal loss would be minimized.

Loose, disturbed, remolded or slough materials should not be allowed to remain in prepared excavation(s). If a suitable founding surface cannot be prepared through mechanical means, then hand cleaning may be necessary.

The surrounding surfaces should be graded so as to direct water away from the excavation.

The sub-grade is sensitive to disturbance and so caution should be exercised during excavation and backfill operations. Wheeled equipment should not be allowed on the sub-grade surface. The sub-grade should be covered once exposed to minimize degradation as the sub-grade is moisture sensitive.

The contractor should be prepared to adjust their construction methodology and excavation profiles as soil and site conditions dictate.

# 6.6 Excavation Parameters

The excavation parameters will be governed by the underside of PWF cribbing pad elevation. The selected elevation should ensure that surface drainage is directed away from the prepared granular base and that positive drainage is attained.

The excavation limits should be defined by the theoretical loading footprint which can be described as a 1:1 slope which extends outwards from the building (exterior edge of PWF pad) perimeter until the founding strata has been attained (plus 1 meter horizontally).

The base of the excavation should be prepared in such a manner that positive drainage (at 2%) is maintained from a centrally located high spot.

The excavation backslopes should be cut at 1:1 to assist in side slope stability.

The actual configuration of the excavation should be verified by the retained geotechnical consultant at the time of construction.

# 6.7 Granular Pad

Any residential building constructed on the lot should be founded upon constructed granular pad comprised of an approved, clean, inorganic, well graded sand and gravel mixture which conform to the attached recommended grain size distribution.

The granular pad should measure  $\sim 1.8$  meters thick and should be comprised of the following;

UNIT	THICKNESS	COMPACTION <sup>C</sup>	COMPOSITION <sup>D</sup>
			20 mm minus
Base	150 mm <sup>A</sup>	100 %	crushed granular aggregate, overlying
			80 mm minus
Sub-base	450 mm	98 %	sub-base course aggregate, overlying
			150 mm minus and/or Class I Rip-Rap
Sub-base	1200 mm <sup>B</sup>	95 %	sub-base course aggregate, overlying
Geotextile	NT A	DT A	Non-woven
Fabric	INA	INA	filter fabric
Sub-grade	NA	95 %	approved native
			sub-grade materials

# Granular Pad

Notes;

- <sup>A</sup> The prepared surface of the granular backfill should be level in the region where PWF pads are to be placed. The granular pad should extend a minimum of 1.0 meters beyond the edge of the pad at these locations.
- <sup>B</sup> The thickness of this unit should be uniform through-out the building load envelope.

If long-term movements are to be reduced and/or if an increased allowable bearing capacity is required, then the sub-base should extend to the underlying coarse grained fluvial deposits provided the site conditions on the adjacent lots allow for it. Additional assessment will be required if this option is to be considered as construction dewatering and thermal protection aspects will need to be carefully assessed, on a case-by-case basis.

<sup>C</sup> – Indicates percent compaction relative to the materials Proctor maximum dry density at (or near,  $\pm 2\%$ ) its optimum moisture content.

Caution should be exercised during compaction as the underlying subgrade materials are moisture sensitive and subject to a loss of strength if disturbed. Non-vibratory (static) rolling may be required.

All materials should be placed in uniform, level lifts that do not exceed 150 mm thick, as measured following compaction. The exception to this would be if Class I Rip-Rap (or equivalent coarse) materials are utilized. Typically these materials are placed in 0.5 meter thick lifts prior to leveling and static rolling.

<sup>D</sup> - If groundwater infiltration is encountered at the sub-grade elevation, then the backfill should be comprised of Class I Rip-Rap or else some other approved coarse fill. The course Class I Rip Rap (or equivalent) should be fully encased in geotextile fabric.

A recommended grain size distribution for the specified imported fills has been attached as Appendix D

Considering the local site elevations, the granular pad should be constructed such that the prepared surface is in the order of 1 meter higher in elevation than the prevailing road grades.

# 6.8 Filter Fabric

Due to the potential degradation of the excavation base and other exposed materials over time, the use of a filter fabric will be required to facilitate backfill operations. The fabric should extend across the excavation base and excavation sidewalls. If successive pieces are required, they should be either sewn or overlapped by a minimum of 1.5 meters. The overlap should be in the same direction as that of advancing backfill operations.

# 6.9 Structural Breaks & Reinforcing

Structural breaks, reinforcement and other similar features should be integrated into the building design to allow for differential movements caused by soil volume changes of the underlying soils. In addition, it should be noted that structures built upon cribbing foundations are inherently more susceptible to seismic action and so this should be considered during design and construction of any residence/structure.

# 6.10 Site Drainage

The granular pad construction and surrounding areas should be graded to direct surface water away from the building structure. Typically, a 2 percent slope will be suitable for this purpose.

Eaves troughs should be incorporated into the roof structure. The discharge/outflows should extend a minimum of 3 meters away from the building structure.

The crawlspace must be protected from rain, snow and the ingress of surface and groundwater at all times.

# 6.11 Inclement Weather

The sub-grade and construction materials should be protected from drying, freezing, snow and surface/groundwater at all times.

# 6.12 Temporary Excavations & Worker Safety

Worker safety is paramount.

Temporary excavations to conventional depths at this site should comply with current regulations under the *Yukon Workers Compensation Board* - *Occupational Health & Safety Act*.

In general, side slopes cut at 1:1 (horizontal/vertical) should allow for adequate stability provided that the depth of the excavation does not exceed 2 meters. If these parameters are to be exceeded, then they should be verified and monitored by qualified geotechnical personnel during the time of construction. The excavation sidewall (slope) stability will be dependent upon the material characteristics, configuration of the excavation, length of exposure, presence of groundwater and other similar factors which should be re-evaluated at the time of construction.

Slope stability will be poor where wet/saturated materials, fills or clean granular materials are encountered and more gradual cut slopes may be required in these areas to minimize the potential for slope failure.

#### 6.13 Surface and Groundwater

As the depth to groundwater will vary with seasonal conditions, the Contractor should be prepared to conduct construction dewatering operations on an as needed basis.

Surface and groundwater should be intercepted and removed from excavations (and construction areas) at all times during granular pad construction to ensure a dry working area.

Caution should however be exercised as lowering of the local groundwater regime may affect nearby structures due to settlement of the underlying soils. More detailed analysis would be required to assess the effects of construction dewatering on neighboring structures (i.e., buildings, utility poles, etc.) if the depth of excavation exceeds 1 meter.

> Government of Yukon - EMR Geotechnical Evaluation and Limited Phase II ESA Lot 2 Block HB Haper Estate Dawson City, Yukon – 2015

23

#### 6.14 Temporary Stockpiles

Stockpiled materials that may be utilized during construction should be protected from segregation and the ingress of snow, rain and surface waters.

#### 6.15 Sub-surface Utilities

Sub-utilities should be embedded in a bedding sand conforming to the grain size specifications provided in the imported fill Appendix. The utility pipe should be established on a base of bedding sand which measures 300 mm thick. In addition, the bedding sand should extend a minimum of 300 mm on all sides of the pipe. The material should be compacted to a minimum of 95% of the materials corresponding Proctor density at (or near) the materials optimum moisture content. If utility trenches are located within the building load envelope, then the materials should be compacted to 98% of the materials corresponding Proctor density at (or near) the materials corresponding Proctor density at (or near) the materials are located within the building load envelope, then the materials should be compacted to 98% of the materials corresponding Proctor density at (or near) the materials corresponding to the imported fill Appendix) encased in filter fabric.

In general, the excavation spoils should be suitable for use as backfill so long as they are not located within the building load envelope or else parking areas. Otherwise the remaining trench backfill should conform to the recommended grain size distributions for imported fills provided in the Appendix.

Pipes should be well insulated to prevent freezing by means of soil cover, physical coating, heat trace or combination thereof.

Where utility trenches penetrate Unit #2 - Organics and Unit #3 - Alluvial Channel Deposits, sloping of the base of the trench away from the building should be

conducted (such that positive subsurface drainage is maintained and the potential for subsurface groundwater inflow from within the existing utility trenches is minimized). The use of a trench plug to minimize the potential of groundwater inflow through the trench should be considered.

Where possible, underground utilities be situated outside of the building perimeter to allow for ease of future maintenance.

#### 6.16 Driveways and Parking Areas

UNIT	THICKNESS	COMPACTION <sup>B</sup>	COMPOSITION
Base	150 mm	100 %	20 mm minus crushed granular aggregate, overlying
Sub-base	300 mm <sup>A</sup>	98 %	80 mm minus sub-base course aggregate, overlying
Geotextile <sup>C</sup>	NA	NA	approved filter fabric
Sub-grade	NA	95 %	approved native sub-grade materials

The structure for driveways and parking areas should be comprised of;

Notes; <sup>A</sup> – If additional fill is required to meet the anticipated design elevations, then a clean, well graded 'pit run' material with maximum particle size of 150 mm can be utilized below the sub-base materials.

 $^{B}$  – Indicates percent compaction relative to the materials Proctor maximum dry density at (or near, ± 2%) its optimum moisture content. All materials should be placed in uniform, level lifts that do not exceed 150 mm thick, as measured following compaction.

Government of Yukon - EMR Geotechnical Evaluation and Limited Phase II ESA Lot 2 Block HB Haper Estate Dawson City, Yukon – 2015 25

<sup>C</sup> – The use of geotextile fabric should be considered if poor subgrade materials are encountered or if additional structural support is required.

A recommended grain size distribution for the specified imported fills has been provided in the Appendices.

# 6.17 Construction Monitoring and Testing

During construction, qualified geotechnical personnel should monitor the excavation and side slopes and inspect all sub-grade surfaces prior to backfill to verify that the prepared sub-grade surface is suitable for use.

Materials testing services should be conducted during granular pad construction to assess the suitability of the imported structural fills through laboratory testing and to verify that adequate compaction has been attained through in-situ field density (compaction) testing.

# 6.18 Foundation Monitoring

As generally all structures in permafrost regions undergo some amount of movement due to underlying changes in the soil volume, the foundation should be monitored and the structure re-leveled on an as needed basis depending upon the design.

#### 7.0 CONCLUSIONS

As the results of the chemical analysis noted hydrocarbon limits within the soil that exceed the recommended *CSR* criteria, the site would be considered contaminated in accordance with the regulations. As such, additional characterization as per the above noted environmental recommendations should be conducted to better assess potential site remediation options.

Following site remediation, the (geotechnical) sub-surface conditions encountered will allow for construction of a granular pad upon which a residential structure can be constructed utilizing a (PWF) cribbing and ventilated crawlspace foundation system prepared in accordance with the recommendations provided herein.

Long-term maintenance through periodic re-levelling will be required throughout the life of the structure to accommodate movements caused by fluctuations in the underlying soil volumes as well as thermal and groundwater regimes.

#### 8.0 LIMITATIONS

This report is intended for the sole use of the *Yukon Government*. No portion of this report may be used as a separate entity; it is intended to be read in its entirety. Any use of this report by a third party is the responsibility of such third party.

The recommendations provided are based upon the subsurface conditions encountered at the time of our investigation, current construction techniques and environmental standards and generally accepted engineering practices. The content within this report reflects our best judgment in light of the information available to our firm at the time of report preparation. The anticipated construction conditions have been discussed, but only to the extent that they may influence design decisions. Any references to construction methods contained herein, express our opinion and are not intended to direct contractors on how to carry out construction. Prospective contractors should be aware that the data presented may not be sufficient to assess all factors that may have an effect upon construction. While references to underground utilities have been made, the locations of sub-surface utilities should be verified by prior to construction.

It is important to emphasize our evaluation is based, in fact, on a random sampling of the subject property site. Our comments are based upon the results obtained at the borehole and sample locations. Due to the geomorphological nature of the deposits encountered, interpolations of subsurface conditions between the borehole and other locations on the site have not been made or been implied. The soil and ground conditions at this site are dynamic and thus the subsurface conditions will vary over time.

The recommendations have been provided without consideration to the effects of deep and long-term thaw of local and/or regional permafrost which may stem from

global warming, the proposed or nearby construction/structures or other causes. In addition, geotechnical consideration regarding seismic constraints have not been considered. Structures built upon cribbing foundations are inherently more susceptible to seismic action and so this should be considered during design and construction.

Should unexpected conditions be encountered during construction, our firm should be notified immediately in order to confirm the suitability of our recommendations. If required, our firm may alter or modify our recommendations at such time.

# 9.0 CLOSURE

Thank you for allowing our firm to provide you with the above noted assessment. While we trust the information will suit your purposes, please feel free to contact the undersigned if you have any questions.

Respectfully Submitted,

# CHILKOOT GEOLOGICAL ENGINEERS LTD.



Tares Dhara, P.Eng. Senior Geotechnical Engineer

TD/td

Geotechnical Evaluation & Limited Phase II ESA Lot 2, Block HB, Haper Estate, 8338A CLSR - Dawson, Yukon – 2015 FIGURE 1 – Site Location



Based map modified from Google Earth – Limits are approximate

Compiled Aug.19, 2015 by T.Dhara

Geotechnical Evaluation & Limited Phase II ESA Lot 2, Block HB, Haper Estate, 8338A CLSR - Dawson, Yukon – 2015 FIGURE 2 – Borehole and Hand Sample Locations



Based map modified from Google Earth – Limits are approximate

# **APPENDIX** A

**Borehole Soil Logs** 

# **NOTES ON SOIL LOGS**

#### **Soil Description**

The soil is named after its principal component and modified by other components as follows;

Perce	ent of Compo	onent	Modi	fier
	> 15 %		XXX	- ey
	11% to 15	<sup>6</sup> %	some	XXX
	5% to 10%	6	trace	XXX
Exan	nples;			
	<u>SILT</u>	SAND	<u>GRAVEL</u>	Description
	6	32	62	Sandy Gravel trace Silt
	55	6	39	Gravelly Silt trace Sand
	43	36	21	Silty Gravelly Sand

Note: In the cases where the coarse fraction (sand & gravel) comprise > 50% of the sample, then the larger component of the coarse fraction becomes the principal component.

# **Undrained Shear Strength of Cohesive Soils**

	Undrained S	hear Strength
Consistency	p.s.f	kN/m <sup>2</sup>
Very Soft	< 375	<20
Soft	375-750	20-40
Firm	750-1500	40-75
Stiff	1500-3000	75-150
Very Stiff	3000-6000	150-300
Hard	>6000	<300

# CHILKOOT GEOLOGICAL ENGINEERS LTD.

# **<u>Relative Density (Qualitative Classification)</u>**

Cohesive So	ils
Very Soft	- Exudes between fingers when squeezed by hand
Soft	- Moulded by light finger pressure
Firm	- Moulded by strong finger pressure
Stiff	- Cannot be moulded by fingers – Can be indented by thumb
Very Stiff	- Can only be indented by thumbnail
Hard	- Cannot be indented by thumbnail

# Granular Soils

Very Loose	- Considerable sidewall sloughage noted
Loose	- Some sidewall sloughage noted – Easy digging
Compact/ Medium-Dens	- Unimpeded excavation – little to no sidewall sloughage se
Dense	- Considerable effort required during excavation – Stable vertical sidewalls
Very Dense	- Extreme difficulty in excavation

# Soil Log - Sample Type

<u>Symbol</u>	
$\square$	
$\triangle$	

**Grab Samples** Retained from excavation sidewall or base

**Test Pitting** 

Auger Sample Retained from auger flighting

**Drilling** 



**Bucket Sample** Retained from leading edge of excavator bucket **Split-Spoon Sample** Retained from Split-Spoon sampler tube

# **Relative Moisture**

Described as - *dry, damp, moist, wet* or *saturated* - relative to the principal soil matrix.

For example, a moisture content of 10 percent may be classified as '*moist*' for a coarse grained soil (sand or gravel) but '*damp*' for a fine grained (silt) soil.

The moisture content is recorded as a percentage (%) of the weight of water within the soil sample relative to the dry weight of the sample.

# **Recovery**

Refers to the (linear) amount of sample retained after driving the Split Spoon (SPT) sampler tube 18 inches.

Recorded as a percentage (i.e. 12 inch sample/18 drive = 66 %)

# N-Value

Refers to the total number of blows required to drive the Split Spoon sampler tube the final 12 inches of the 18 inch drive.

# Relative Density based upon SPT 'N' Value

Non-cohesive ((	Granular) Soil	Cohesive (	Clayey) Soils
Relative Density	Blows per Foot ( N-value )	Consistency	Blows per Foot ( N-value )
Very Loose	< 5	Very Soft	0 to 2
Loose	5 to 9	Soft	3 to 4
Compact	10 to 29	Firm	5 to 8
Dense	30 to 50	Stiff	9 to 15
Very Dense	> 50	Very Stiff	16 to 30
		Hard	> 30



Figure 18. UNIFIED SOIL CLASSIFICATION SYSTEM

Kaplar, 1966)						1	
1: Description of soil phase (independent of frozen state)	Classify	soil phase by the	unified soil classification s	ystem	Classify soil phase	by the unified soil classification system	
	Major	group	Subgr	dila		Pertinent properties of frozen materials which can be measured	Those
	Description	Designation	Description	Designation	Field identification	by physical tesis to supplement field identification	characteristics
etooff dry.	Segrepated ice noi		Ponty bended or friable No	L Z	Identify by visual examination: to determine presence of excess rice, use procedure under note (3) and hand magnifying lens as necessary. (or soils not fully	In-place terriperature Density and void rutio a. In frozen state b. After thawing in place	yltensU thene-weath
lt : Description of		•	Weli bonded Excess ice	÷ ¢	salurated estumate degrac of sec saturation (medium, low); note presence of crystals or of ice coatings around larger particles	Water content (total 13,0), including ice) a. Average b. Distribution	
frozen soil			Individual ice crystals or inclusions	٨x	For ice plase, record the following as applicable	Sirength a. Contpressive b. Tensile c. Shear	
			lee coatings on particles	Vc	Location Size Drientation Shape Thickness Partern of	d, Adfreze Elustic properties Plustic properties	3
	argregated ice visible by tye fice 25 mm or fess thick)	>	Pandom or irregularly oriented icc formations	٨٢	Length arrangement Spucing Hardness Structure Arr part IIf below	Thennal properties lee crystal structure (using optical instructurents) a. Orientation of axes b. Crystal size	Usuafiy thaw-unstable
<ul> <li></li></ul>	•	·	Stratified or distunctly oriented ice formations	57	Lotor visible Estimute volume of visible segregated ice present as percent of total sumple volume	c. Crystaf shape d. Pattern of arrangement	
11. Description of	Ice greater	-	lce with soil inclusions	ICE + soil type	Designate material as ice and use descriptive terms as follows. usually one iten fram each group. as upplicuble: flurdness: hard, soft (of mass, not of individual events)	Same as part 11 above, as anoticable, with special emphasis	2: 
substantial ice strate	thán 25 min thick	<u>ل</u>	lee without soil inclusions	ICE	Structure: cleur, cloudy, porous, cundled granular, stratified Color: colorless, pray, blue Admistures: contuins few thin silt inclusions	on ice crystał structure	

Table 1.2 Description and classification of frozen soils (adapted from Linuell and Kaplar, 1966)

•

-

(see notes on p. 32)

# CHILKOOT GEOLOGICAL ENGINEERS LTD.

5B Bennett Road, Whitehorse, Yukon (867) 335-2085 chilkoot@northwestel.net

# BOREHOLE LOG

840	Clie	nt: Y	ukon Government - Energy,	Mines & Res	sour	ces				Date Drilled	: August 8, 20 100 00 meters	15	BO	REHO	E
	Proj	ect : koot I	Geotechnical Evaluation Project No. : 200-006-15							Depth of BH Instrumenta	tion: NA		<b>1</b>	-15 neet 1 of 1	I
-	Dor	th			Fi	eld S	Samp	le	) (11), (11)	Lab	oratory Results	:(%)	Ŷ	0	(c
Elev. (m	ft		Stratigraphic Descrip	Relative	umber	mperature egrees C)	% Vievo	kg/cm2)	SPT .N	▲ - FINES	●-SAND MC PL I ④ U	GRAVEL	ISCS/NF Depth (m	Symb	Elev. (r
		0.08	Density	Moisture	z	G H	Aer.	a.		20	40 60	80	ORG	AL ALL	100
99.5	1.0	0.5	Compact Organic Silt and Rootlets, non-plastic, black FILL - SILTY SAND	damp	1	NA	NA	NA	NA	© 17.3			FILL ->		99.5
- - 99.0- -	3.0		graded, fine grained, firm non-plastic, brown	/ moist	22	NA	NA	20	NA		0		1.0		99999
- - 98.5- -	4.0 5.0	1.50	with black organic <u>inclusions</u> SANDY SILT some compact Rootlets - non-							0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	4.6	79.7.	ML -		98.5 98.5
- - - - - 0.86	6.0	2.0	plastic, brown with black organic intrusions in size to 5 mm.										SM		98.0
- - 97.5-	8.0	<u>2.44</u> 2.5	SILTY SAND some GRAVEL - poorly graded, fine to medium grained	moist	3	NA	NA	NA	NA NA	0.00 10.00 12 12	39.1.	Caved			97.56 97.5
- 97.0	9.0	3.0	brown - w/ orange streaks of oxidation GRAVELLY SAND -				, ere			3.9		244	ŜP -		97.0
- - 96.5-	11.0	3.5- 3.66-	grained, grey-brown grained, grey-brown loose possible cobbles - well washed	wet									<b>₽yy</b>		96.58 96.5 96.34
- - 36.0-	13.0	4.0	loose <u>- as above but wet</u> SANDY GRAVEL - poorly graded,	moist	5	NA	NA	NA	NA	⊙ 8.2 ▲ ⊙			GR		96.0
- 	14.0	4.27	- well washed Lot 2 Block HB End of Borehole							ষ্ট.0 N	5476 600			<u>. No o</u>	95.73 95.5
5.0	111111		Encountered @ 3.42 m below the ground surface											1	95.0
4.5	looto	-	at 4.27 m. below the existing ground surface.												94.5
- - - 94.0- -		-											1111		94.0
- - - - - - - - - -	mhur	-													93.5
		-													
<u>.3.0</u> . 1	Drill	ed By	: Donjek Services	Drill Type :	CME	E 750	) (FN	160)		Auger Type	150 mm Solid	Stem B	iit Type : F	ish Tail	93.0
¥	During D	Water Drilling At End	Level(s) VAfter Drilling of Drilling	Logged By Date : At	: T.E ugus	)hara t 8, 2	a, P.I 2015	Eng.		Data Entry B Date : Aug	By : T.Dhara, P.I g 15-21, 2015	Eng. R	Reviewed I Date : Aug	By: 🌮 ust 31, 2	2015

# CHILKOOT GEOLOGICAL ENGINEERS LTD.

5B Bennett Road, Whitehorse, Yukon (867) 335-2085 chilkoot@northwestel.net

i

# BOREHOLE LOG

	Clie	nt: Y	/ukon Government - Energy	y, Mines &	Reso	urce	es				Date Drilled		st 8, 20	15		BOR	EHO	E
	Proj	ect : koot l	Geotechnical Evaluation Project No. : 200-006-15	оск нв							Depth of BH	1: 4.41 n ition: 2"	neters Monitor	ing Well		2 She	-15 et 1 of	1
Ê	Dep	oth			-	Fiel	ld Sa	amp	le		Lab	oratory	Results	(%)	CM	Ê	lo	Ê
Elev. (	ft	m	Stratigraphic Descr Relative Density	ription Relative Moisture	Type	Number	(degrees C)	Recovery %	Penetromete (kg/cm2)	SPT 'N'	▲- FINES	●-S N PL → ( 40	iand ic ●   ⊔ 60	■- GRAV		Depth (	Syml	Elev. 1
99.5	1.0 1111	0.06	soft ORGANICS - firm ORGANICS - Organic Silt and Rootlets, non-plasti black FILL - SILTY SANI to SANDY SILT trac Brottets - poorty	c, damp		7	NA	33	2.0	10		⊙ 38.8			FIL			100 99,92 99.55 99.5 99.24
99.0 - - - - 98.5	3.0 4.0	1.0 <u>1.22</u> - 1.5-	graded, fine grained non-plastic, black with black organic inclusions SILTY SAND to	a,	1	8	NA	22	NA	8	19.4				SI			99.0 98.78 98.5
- - - 98.0- -	6.0111111 7.01	2.0	SAND SILT some Rootlets - fine grained, brown with seams of black organics up to 3 mr nossible fill	n   n									*****		2.0			98.0 · 97.72
97.5-	8.0 9.0	2.5-	sold dense SANDY SILT - non plastic, fine grained grey-brown SANDY GRAVEL poorly graded,	- hoist		9	NA	56	NA	30	⊙ 5				G	4 999	200	97.7 97.5 97.26
97.0- - - 96.5- -	10.0 11.0 12.0	3.0	compact Compact SANDY GRAVEL poorly graded,	wet	ŀ	10	NA	17	NA	22	© 92				 Gi	A		97.0 - 96.65 96.5
96.0-	13.0	4.0	brown - well washed gravel in size to 50 mm	<u>-</u>		100									4.0		<u>, 10</u>	96.0 · 95.59
95.5 - - - 95.0 - -	111111111		End of Borehole Groundwater Encountered @ 3.4 m below the groun surface	7 d														95.5 95.0 ·
94.5- - -	1111111		2" Monitoring Wel installed to 4.41 m below the ground surface Borehole terminate	d														94.5
94.0- - -	111	1.1.1	at 4.41 m. below th existing ground surface.	e														94.0 ·
93.5- - - -	linhu	1111														1111		93.5
93:0 <sup>-</sup>				1	Drille Drill 1	d By Type	/:D	onje ME	ek Se 750	ervic (FN	: : : es 0)	: : Ai Bi	uger Tyj t Type '	be : 200 Carbide	mm Hollov Button	v Ster	n (	93.0
Ψ	V During D. Y	Water nilling At End	Level(s) Verter Drilling of Drilling	Logged I Date :	By : T Augi	Dhust 8	ara, 3, 20	. Р.Е 015	ing.		Data Entry B Date : Aug	y : T.Dha I 15-21, :	ara, P.E 2015	ng.	Review Date : /	ved By Augus	y: Ø st 31, 2	:015

# **APPENDIX B**

# **Results of**

**Grain Size Distribution Analysis** 



# CHILKOOT GEOLOGICAL ENGINEERS LTD.

5B Bennett Road, Whitehorse, Yukon



# CHILKOOT GEOLOGICAL ENGINEERS LTD.

5B Bennett Road, Whitehorse, Yukon (867) 335-2085 chilkoot@northwestel.net

#### GRAIN SIZE ANALYSIS - ASTM D422-633



# **APPENDIX C**

# **Results of**

**Anaytical Analysis** 

Exova T: +1 (604) 514-3322 #104, 19575-55 A Ave. F: +1 (604) 514-3323 Surrey, British Columbia E: Surrey@exova.com V3S 8P8, Canada W: www.exova.com



#### Analytical Report

Bill To:	Chilkoot Geological Engineering	Project:		Lot ID:	1087728
Report To:	Chilkoot Geological Engineering	ID:		Control Number:	
	PO 31146	Name:		Date Received:	Aug 13, 2015
	Whitehorse, YT, Canada	Location:	Dawson City, Yukon	Date Reported:	Aug 19, 2015
	Y1A 5P7	LSD:		Report Number:	2033949
Attn:	Tares Dhara	P.O.:			
Sampled By:	Chilkoot - T. Dhara	Acct code:			
Company:					

		Reference Number Sample Date Sample Time Sample Location Sample Description	1087728-1 Aug 10, 2015 NA Lot 2 Soil			
Analyte	<u></u>	Units	Results	Results	Results	Nominal Detection
Extractable Petroleum Hy	drocarbons - Soil	an a				Cinik
FPHs10-19	Drv Weight	ug/g	174			20
EPHs19-32	Dry Weight	ug/g	1140			20
LEPHs	Dry Weight	ug/g	174			20
HEPHs	Dry Weight	ug/g	1140			20
Soil % Moisture	, ,					
Moisture	Soil % Moisture	%	27.80			0.1
Polycyclic Aromatic Hydr	ocarbons - Soil					
Acenaphthene	Dry Weight	ug/g	< 0.03			0.03
Acenaphthylene	Dry Weight	ug/g	< 0.03			0.03
Anthracene	Dry Weight	ug/g	0.06			0.03
Benzo(a)anthracene	Dry Weight	ug/g	0.04			0.03
Benzo(a)pyrene	Dry Weight	ug/g	0.05			0.03
Benzo(b)fluoranthene	Dry Weight	ug/g	0.06			0.03
Benzo(g,h,i)perylene	Dry Weight	ug/g	<0.03			0.03
Benzo(k)fluoranthene	Dry Weight	ug/g	< 0.03			0.03
Chrysene	Dry Weight	ug/g	0.05			0.03
Dibenzo(a,h)anthracene	Dry Weight	ug/g	<0.03			0.03
Fluoranthene	Dry Weight	ug/g	0.06			0.03
Fluorene	Dry Weight	ug/g	<0.03			0.03
Indeno(1,2,3-c,d)pyrene	Dry Weight	ug/g	< 0.03			0.03
2-Methylnaphthalene	Dry Weight	ug/g	<0.03			0.03
Naphthalene	Dry Weight	ug/g	< 0.03			0.03
Phenanthrene	Dry Weight	ug/g	< 0.03			0.03
Pyrene	Dry Weight	ug/g	0.10			0.03
PAH - Soil - Surrogate Re	covery					
2-Fluorobiphenyl	PAH - Surrogate	%	105			50-130
Naphthalene-d8	PAH - Surrogate	%	79			50-130
p-Terphenyl-d14	PAH - Surrogate	%	112			60-130
Quinoline-d7	PAH - Surrogate	%	84			50-130

Exova	T: +1 (604) 514-3322
#104, 19575-55 A Ave.	F: +1 (604) 514-3323
Surrey, British Columbia	E: Surrey@exova.com
V3S 8P8, Canada	W: www.exova.com

Terms and Conditions: www.exova.com/about/terms-and-conditions

# Analytical Report



Bill To:	Chilkoot Geological Engineering	Project:		Lot ID:	1087728
Report To:	Chilkoot Geological Engineering	ID:		Control Number:	
	PO 31146	Name:		Date Received:	Aug 13, 2015
	Whitehorse, YT, Canada	Location:	Dawson City, Yukon	Date Reported:	Aug 19, 2015
	Y1A 5P7	LSD:		Report Number:	2033949
Attn:	Tares Dhara	P.O.:			
Sampled By:	Chilkoot - T. Dhara	Acct code:			
Company:					

		Reference Number Sample Date Sample Time Sample Location Sample Description Matrix	1087728-1 Aug 10, 2015 NA Lot 2 Soil			
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mono-Aromatic Hydroca	rbons - Soil					
Benzene	Dry Weight	ug/g	< 0.02			0.02
Toluene	Dry Weight	ug/g	< 0.05			0.05
Ethylbenzene	Dry Weight	ug/g	< 0.05			0.05
Total Xylenes (m,p,o)	Dry Weight	ug/g	< 0.05			0.05
Styrene	Dry Weight	ug/g	< 0.05			0.05
Methyl t-Butyl Ether	Dry Weight	ug/g	< 0.05			0.05
Volatile Petroleum Hydro	ocarbons - Soil					
VHs6-10	Dry Weight	ug/g	<50			50
VPHs (VHs6-10 minus BTEX)	Dry Weight	ug/g	<50			50
Field Preservation	on		Yes			
Methanor red reservau	UT .					

Exova T: +1 (604) 514-3322 #104, 19575-55 A Ave. F: +1 (604) 514-3323 Surrey. British Columbia E: Surrey@exova.com V3S 8P8, Canada W: www.exova.com



#### Analytical Report

 Bill To:
 Chilkoot Geological Engineering
 Project:
 Control

 Report To:
 Chilkoot Geological Engineering
 ID:
 Control

 PO 31146
 Name:
 Date R

 Whitehorse, YT, Canada
 Location:
 Dawson City, Yukon
 Date R

 Y1A 5P7
 LSD:
 Report

 Attm:
 Tares Dhara
 P.O.:
 Sampled By:
 Chilkoot - T. Dhara
 Acct code:

Lot ID:	1087728
Control Number:	
Date Received:	Aug 13, 2015
Date Reported:	Aug 19, 2015
Report Number:	2033949

		Reference Number Sample Date Sample Time Sample Location Sample Description	1087728-7 Aug 10, 2015 NA Lot 2			
		Matrix	Water			
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Metals Total						12 19 19 19
Calcium	Total	mg/L	220			0.05
Iron	Total	mg/L	464			0.01
Magnesium	Total	mg/L	117			0.05
Manganese	Total	mg/L	17.1			0.005
Potassium	Total	mg/L	27.5			0.1
Silicon	Total	mg/L	115			0.05
Sulfur	Total	mg/L	21.7			0.1
Sodium	Total	mg/L	27.8			0.02
Titanium	Total	mg/L	4.27			0.001
Trace Metals Total						
Aluminum	Total	mg/L	133			0.005
Antimony	Total	mg/L	<0.02			0.0002
Arsenic	Total	mg/L	0.25			0.0002
Barium	Total	mg/L	4.3			0.001
Beryllium	Total	mg/L	0.007			0.00004
Bismuth	Total	mg/L	<0.100			0.001
Boron	Total	mg/L	<0.5			0.004
Cadmium	Total	mg/L	0.0139			0.00001
Chromium	Total	mg/L	0.39			0.0004
Cobalt	Total	mg/L	0.200			0.00002
Copper	Total	mg/L	0.6			0.001
Lead	Total	mg/L	0.33			0.0001
Lithium	Total	mg/L	0.211			0.001
Molybdenum	Total	mg/L	0.04			0.0001
Nickel	Total	mg/L	0.7			0.001
Selenium	Total	mg/L	<0.06			0.0006
Silver	Total	mg/L	0.00759			0.00001
Strontium	Total	mg/L	0.9			0.001
Tellurium	Total	mg/L	<0.01			0.0001
Thallium	Total	mg/L	0.0029			0.00001
Thorium	Total	mg/L	0.0421			0.0004
Tin	Total	mg/L	0.02			0.0001
Uranium	Total	mg/L	<0.04			0.0004
Vanadium	Total	mg/L	0.51			0.0001
Zinc	Total	mg/L	1.8			0.001
Zirconium	Total	mg/L	0.02			0.0001

Terms and Conditions: www.exova.com/about/terms-and-conditions

Exova	T: +1 (604) 514-3322
#104, 19575 - 55A Avenue	F: +1 (604) 514-3323
Surrey, B.C.	E: Surrey@exova.cor
V3S-8P8, Canada	W: www.exova.com



#### Hydrocarbon Chromatogram

Bill To: Report To:	Chilkoot Geological Engineering Chilkoot Geological Engineering PO 31146	Project ID: Name: Location:	Dawson City, Yukon	Lot ID: Control Number: Date Received:	<b>1087728</b> Aug 13, 2015
		LSD:		Date Reported:	Aug 19, 2015
	Whitehorse, YT, Canada Y1A 5P7	P.O.:		Report Number.	2033949
Attn:	Tares Dhara				
Sampled by: Company:	Chilkoot - T. Dhara				

Exova Number: 1087728-1 Sample Date: Aug 10, 2015 Sample Description: Lot 2



Exova	T: +1 (604) 514-3322
#104, 19575 - 55A Avenue	F: +1 (604) 514-3323
Surrey, B.C.	E: Surrey@exova.com
V3S-8P8, Canada	W: www.exova.com

#### Hydrocarbon Chromatogram



Bill To: Report To:	Chilkoot Geological Engineering Chilkoot Geological Engineering PO 31146	Project ID: Name: Location: LSD:	Dawson City, Yukon	Lot ID: Control Number: Date Received: Date Reported:	<b>1087728</b> Aug 13, 2015 Aug 19, 2015
	Whitehorse, YT, Canada Y1A 5P7	P.O.:		Report Number:	2033949
Attn:	Tares Dhara				
Sampled by: Company:	Chilkoot - T. Dhara				

Exova Number: 1087728-4 Sample Date: Aug 10, 2015 Sample Description: Lot 2



Terms and conditions: www.exova.ca/terms&conditions.html

# CHILKOOT GEOLOGICAL ENGINEERS LTD.

# APPENDIX D

# Recommended Grain Size Distribution for Import Fills

Gran E Pit Run		
Sieve Size (mm)	% Passing By Wt	
200	100	
80	75-100	
25	55-100	
12.5	42-84	
5	26-65	
1.25	11-47	
0.315	3-30	
0.08	2-15	
LA Abrasion		
35 % Max Loss		

80 mm minus		
Sub-base		
Sieve	% Passing	
Size (mm)	By Wt	
80	100	
25	60-100	
12.5	40-90	
5	20-65	
1.25	9-35	
0.315	3-15	
0.08	0-8	
LA Abrasion		
35 % Max Loss		

Clear		
Stone		
Sieve	% Passing	
Size (mm)	By Wt	
28	100	
20	70-100	
12.5	55-100	
10	30-80	
5	0-40	
2	0-10	
NA	NA	
LA Abrasion		
35 % Max Loss		

6			
	20 mm minus		
	Base Course		
	Sieve	% Passing	
	Size (mm)	By Wt	
	20	100	
	12.5	64-100	
	5	36-72	
	1.25	12-42	
	0.315	4-22	
	0.08	3-6	

Class III Rip-Rap		
Sieve	% Passing	
Size (mm)	By Wt	
1200	100	
900	80	
800	50	
500	20	

Bedding Sand		
Sieve	% Passing	
Size (mm)	By Wt	
10	100	
5	80-100	
2	55-100	
0.63	25-65	
0.25	10-40	
0.08	2-10	

Class I Rip-Rap		
Sieve	% Passing	
Size (mm)	By Wt	
450	100	
350	80	
300	50	
200	20	

Class II		
Rip-Rap		
Sieve	% Passing	
Size (mm)	By Wt	
800	100	
600	80	
500	50	
300	20	



APPENDIX E - SELECTION OF PHOTOS

Photo # 1 (above) – Site conditions from back alley.

Photo # 2 (right) – BH 1-15 – 0 to 5 feet





Photo # 3 (left) – Sample No.10 - Sandy Gravel

Photo # 4 (right) – Site conditions following well installation



Geotechnical Evaluation Lot 2, Block HB, Haper Estate, 8338A CLSR Dawson City, Yukon - 2015