



WELL 2592  
 N 7 104 220  
 E 592 363  
 DRILLERS REPORT  
 NO.: 802030006



NOTES:  
 1. UTM COORDINATES OBTAINED WITH A HAND HELD GPS USING NAD83 SYSTEM AND ARE CONSIDERED TO BE ACCURATE TO 10.0 m, APPROXIMATELY.  
 30 m RADIUS FROM WATER WELL FOR CONSIDERATION OF PROXIMITY TO POTENTIAL CONTAMINANT SOURCES.

		<b>SMALL PUBLIC WATER SYSTEMS ASSESSMENT</b> NORTHERN REGION											
DESIGNED BY: R. MARTIN DRAWN BY: J. BUICK DATE: SEPT. 2005 SCALE: AS SHOWN PROJECT No.: 1260002.004 ACAD FILENAME: 004-NORTHERN_REGION		<b>GOVERNMENT OF YUKON</b> <b>HIGHWAYS &amp; PUBLIC WORKS</b> KLONDIKE VALLEY FIRE HALL BUILDING # 2592 SITE LOCATION DIAGRAM WELL ID: 2592											
CLIENT:		REVISION ISSUE 0											
		HIGHWAYS and Public Works Property Management Branch											
<table border="1"> <thead> <tr> <th>No.</th> <th>ISSUED FOR CLIENT REVIEW</th> <th>DATE</th> <th>APPROVED</th> <th>REVISION</th> </tr> </thead> <tbody> <tr> <td>0</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		No.	ISSUED FOR CLIENT REVIEW	DATE	APPROVED	REVISION	0					FIGURE No. <b>FIGURE 2592-A</b>	
No.	ISSUED FOR CLIENT REVIEW	DATE	APPROVED	REVISION									
0													





DRAWING IS BASED UPON SCHEMATIC PROVIDED BY BERT ALBISSER OF AQUA TECH SUPPLIES AND SERVICES LTD.

		PROJECT SMALL PUBLIC WATER SYSTEMS ASSESSMENT NORTHERN REGION	
CLIENT 		TITLE WATER SYSTEM DISTRIBUTION/TREATMENT SCHEMATIC SYSTEM ID.: 2592 KLONDIKE VALLEY FIRE HALL - DAWSON, YT.	
DATE SEPT., 2005	DWN. JSB	CHKD. RMM	FILE NO. 1260002.004
		DWG.: FIGURE 2592-B	

Northern Region – Klondike Valley Firehall  
Building # 2592

DISTRIBUTION & TREATMENT SYSTEM DATA

Item	Description	Manufacturer	Model	Part No.	Serial No.	Size
1	Sub Pump	MONARCH	1/2 HP			4" -
2	STORAGE TANKS	N/A	1000GAL	ROUND		6'6" x 5'
3	JET PUMP	MYERS	H750S			1/2 HP
4	PRESSURE TANK	CHALLENGER	PC 66			20 GAL
5	CHLORINATOR	GRUNDFOS	DMEB-10			
6						
7						
8						
9						
10						

**TABLE 2592 - 1: SUMMARY OF BACTERIOLOGICAL RESULTS**

<b>Building #</b>	<b>Building Name</b>	<b>Number of Sampling Events</b>	<b>Time Period over which Sampling was Done</b>	<b>Any Positive Total Coliform Results? (yes or no)</b>	<b>Fraction of Positive Total Coliform Results vs. Total Sampling Events</b>	<b>Any positive E.Coli results? (yes or no)</b>	<b>Most Recent Sampling Event Available for EBA Review</b>	<b>Is Most Recent Result Positive?</b>
2592	Klondike Valley Fire Hall	10	Oct-04 to Jun-05	yes	1/10	no	9-Jun-05	yes



Table 2592 - 2: Water Quality Results

SOURCE:		Building - 2592 Klondike Valley Fire Hall		GCDWQ Criteria		
Location/ Resident	Dawson City					
Address						
Treatment	None					
Disinfection	Chlorination					
Source of Water	On-site well					
Purpose of Sampling	Base Line	Additional Sampling				
Sample Location						
Date Sampled	2-Jun-04	19-Aug-05	Lower	Upper Limit		
Physical Tests (ALS)			AO	MAC	AO	
Colour (CU)	<5.0				15	
Conductivity (uS/cm)	312					
Total Dissolved Solids	162				500	
Hardness CaCO3	152		AO >200 = poor, > 500 unacceptable <sup>A</sup>			
pH	7.79		6.5		8.5	
Turbidity (NTU)	<0.10			1	5	
UV Absorbance						
% UV Transmittance						
Dissolved Anions (ALS)						
Alkalinity-Total CaCO3	85.5					
Chloride Cl	1.95				250	
Fluoride F	0.062			1.5		
Silicate SiO4						
Sulphate SO4	61.8				500	
Nitrate Nitrogen N	0.21			10		
Nitrite Nitrogen N	<0.10			3.4		
Ammonia Nitrogen N						
Total Phosphate PO4						
Total Metals (ALS)						
Aluminum T-Al	<0.010			0.1		
Antimony T-Sb	<0.00050			0.006		
Arsenic T-As	<0.0010			0.025		
Barium T-Ba	0.076			1		
Boron T-B	<0.10			5		
Cadmium T-Cd	<0.00020			0.005		
Calcium T-Ca	42.5					
Chromium T-Cr	<0.0020			0.05		
Copper T-Cu	0.039			1		
Iron T-Fe	<0.030				0.3	
Lead T-Pb	<0.0010			0.01		
Magnesium T-Mg	11.1					
Manganese T-Mn	<0.0020				0.05	
Mercury T-Hg	<0.00020			0.001		
Potassium T-K	0.61					
Selenium T-Se	<0.0010			0.01		
Sodium T-Na	3.1				200	
Uranium T-U	0.00028			0.02		
Vanadium T-V						
Zinc T-Zn	<0.050				5	
Trihalomethanes						
Bromodichloromethane		<0.0010				
Bromoform		<0.0010				
Chloroform		0.0012				
Dibromochloromethane		<0.0010				
Total Trihalomethanes		<0.0040				
Organic Parameters						
Tannin and Lignin						
Total Organic Carbon C		1.25				
Haloacetic Acids						
Bromoacetic Acid		<0.0020				
Bromochloroacetic Acid		<0.0020				
Chloroacetic Acid		<0.020				
Dibromoacetic Acid		<0.0020				
Dichloroacetic Acid		<0.0020				
Trichloroacetic Acid (TCA)		<0.0020				
Field Chemistry (EBA)						
pH		7.81	6.5		8.5	
TDS (ppm)		142			500	
EC (uS/cm)		286				
Temperature (°C)		6.3				
Free Available Chlorine		0.42				

Notes:

A. Guidelines indicated for hardness are not CDWQG, rather they are general aesthetic guidelines - exceedences are indicated in yellow highlighting.

italics and underline indicates exceedence of proposed MAC (ie. arsenic)

**Bold with Yellow** highlighting indicates exceedence of CDWQG Aesthetic Objective (AO)

**Bold Underline with Yellow** highlighting indicates exceedence of CDWQG MAC

Results are expressed as milligrams per litre except for pH and Colour (CU)

Conductivity (umhos/cm), Temperature (°C) and Turbidity (NTU)

< = Less than the detection limit indicated.

AO = Aesthetic Objective

MAC = Maximum Acceptable Concentration (Health Based)



# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## SMALL PUBLIC WATER SYSTEM ASSESSMENT

### PART A: EBA Site Inspection

Inspector: Ryan Martin, Luke Lebel

Date August 19, 2005

WELL ID #	Owner	Location Description
2592	YTG	Klondike Valley Fire Hall

#### 1. Well Location and Potential Contaminant Sources

a. General location of well: (Community, Subdivision, etc.)

Dawson City

b. Specific location: (Road or street, Building number, name of owner and/, legal description,

Klondike Highway

c. GPS location: N 7104220 E 592363 elev 379m ± 11m

d. Is there electric power?  Yes  No

e. Is there outside water access?  Yes  No public fill

f. Does the well system have:

15 or more service connections to a piped distribution system? If so how many \_\_\_\_\_

Fire Hall and public fill

5 or more delivery sites on a trucked distribution system? If so how many \_\_\_\_\_

g. Nearest building, specify fire hall

h. Distance from well to building ~13m

i. If there is an effluent disposal field, is its location known?  Yes  No

j. Distance from well to nearest point of known field: 40m (36m to tank)

k. Well location relative to field:  upslope  downslope  lateral

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

l. Is there any part of a sewage disposal system(s) or other potential sources of pollution that may pose a health and safety risk within 30 m?  Yes  No

m. Is the well located within 300 m from a sewage lagoon or pit?  Yes  No *unlikely*

n. Is the well located within 120 m from a solid waste site or dump, cemetery?  Yes  No *unlikely*

o. Is the infrastructure protecting the wellhead, pumphouse, storage tank and/or water treatment plant designed and secured to prevent:

Unauthorized access by humans?  Yes  No *Unlocked enclosure* Entrance by animals?  Yes  No *Access possible*

p. Is well site subject to flooding?  Yes  No

q. Is the well site well drained?  Yes  No

r. Is there a buried fuel tank on the property?  Yes  No

If yes, is it  in use  abandoned

Is the location known?  Yes  No

Distance from the well to known buried tank \_\_\_\_\_

s. Are there any other known contaminant sources on the property?

Yes  No Describe \_\_\_\_\_

If yes, specify the source:  dump  sewage lagoon  cemetery  other

Potential Source 1: Road; Distance from well to Potential Source 1: 12m

Potential Source 2: Highway; Distance from well to Potential Source 2: 80m

Potential Source 3: \_\_\_\_\_; Distance from well to Potential Source 3: \_\_\_\_\_

Potential Source 4: \_\_\_\_\_; Distance from well to Potential Source 4: \_\_\_\_\_

t. Are there other wells on this property?  Yes  No

How many? \_\_\_\_\_  in use  abandoned  require proper sealing

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## 2. Well and Wellhead information:

- a. When was well installed? Year 1992 Month June
- b. Type:  drilled  dug  sand point  other \_\_\_\_\_
- c. Is there a drillers log for the well:  Yes  No
- d. Is there a surface seal to 6 m  Yes  No  unknown  unlikely
- e. Surface casing:  Yes Diameter \_\_\_\_\_  No
- f. Well casing: Diameter 15cm Material:  steel  plastic  concrete
- g. Depth of well: 41 ft  measured (if possible)  reported  from log
- h. Static water level below ground: 4 ft  
 measured (if possible)  reported  from log  flowing
- i. (If granular) Is the well completed:  open end casing  with a well screen  
 with slotted pipe  unknown other \_\_\_\_\_
- j. (If bedrock) Does the well have a liner?  yes  No  steel  plastic
- k. If there is a well screen: length 5 ft slot size(s) 18 slot  
Location of screen: from 36 ft to 41 ft from log reported
- l. Is there a sump below the screen?  Yes  No
- m. Is the well head:  in pumphouse  in pit  pitless adaptor  in a building  
 in a wooden enclosure other, describe \_\_\_\_\_
- n. If the well head is located in a wooden enclosure,

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- i. Is the well head below grade? describe in detail ~0.7 m below grade
- ii. Are there signs of ponding on the enclosure(e.g. water stains, etc.)?  Yes  No
- iii. Is the wellhead enclosed by fiberglass insulations?  Yes  No styrofoam insulation
- iv. Any evidence of rodents? Specify Access possible
- v. Does the well casing have a proper seal cap?  Yes  No
- If no, describe condition split gasket cap

### 3. Water Supplying This Well:

- a. By definition is the water from a surface water source or under the direct influence of surface water?
- Yes  No  farther investigation required.

If yes is there treatment or disinfection  Yes  No

Explain (filtration, disinfection etc...) chlorination

### 4. Aquifer Supplying This Well:

- a. The aquifer is:  bedrock  granular sediment  unknown
- b. Does water level and/or well capacity show seasonal fluctuation?  Yes  No

### 5. Pump Installation:

- a. Is the well equipped with a pump?  yes  No
- b. Type of pump:  hand  electric submersible  jet
- shallow well centrifugal  other, \_\_\_\_\_
- c. Description: Manufacturer \_\_\_\_\_ Model \_\_\_\_\_
- horsepower \_\_\_\_\_ capacity \_\_\_\_\_ voltage \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

d. Date installed: Nov 1992 By: \_\_\_\_\_

e. For submersible pump, depth of setting below surface 34 ft

f. Drop pipe for submersible pump:  steel  plastic *likely*

g. Pump delivers water to:  pressure tank  elevated tank  other

h. Are there automatic pump controls:  Yes  No

i. Is there provision for taking water samples before water reaches storage?  Yes  No

j. Is there a water meter on the system?  Yes  No

k. Is the pump and piping protected from freezing?  Yes  No

If yes, describe: Heat trace & insulation

l. Comments on pump installation: \_\_\_\_\_  
\_\_\_\_\_

## 6. Conclusions

a. Comments on overall installation:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

b. Recommendations: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## PART B: EBA Site Inspection

Inspector: BERT ALBISSER

Date: AUG 19/05

WELL ID #	Owner	Location Description
<u>2592</u>	<u>YTG</u>	<u>KLONDIKE VALLEY FIREHALL</u>

### 6. Water Treatment

a. Is well water treated?  Yes  No; Type of treatment:

chlorination  iron and or manganese removal  other \_\_\_\_\_

b. Is water entering plumbing or piped distribution system treated with chlorine or another treatment that is as effective as chlorine used to achieve disinfection throughout the system?

Yes  No If so how \_\_\_\_\_

c. If treated with chlorine, is the free residual chlorine concentration less than 0.2 mg/L

Yes  No \_\_\_\_\_ reading.

Tested at \_\_\_\_\_ (location)

d. Is testing for chlorine residual concentration done at the tap (eg. Kitchen faucet) or from representative points in a piped distribution system, including a point from tap at the end line

Yes  No If yes how often? \_\_\_\_\_

e. If the drinking water is being transported by water delivery truck does it have a minimum chlorine free residual of 0.4 mg/L at the time of fill.  Yes  No

### 7. Water Quality (observations):

a. Does the water stain plumbing?  yes  No  slight  severe

Type of stain:  brown  red  black

b. Does the water contain sediment?  Yes  No  occasional  constant

c. Is there an unpleasant odour?  Yes  No  H<sub>2</sub>S  Other \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- d. Is there an unpleasant taste?  Yes  No  brackish  Other \_\_\_\_\_
- e. Is there a history of bad bacterial analyses?  Yes  No  ?
- f. Is there a chemical analysis?  Yes  No  adequate  incomplete
- g. Is there analysis of trihalomethanes (THMs) where the water source is a surface water supply or a well under the direct influence of surface water?  Yes  No
- h. Is the drinking water tested daily with an accurate reading chlorine test kit capable of reading in the range 0 to 3.5 mg/L of free chlorine residual in increments of 0.1mg/L?  Yes  No  unknown
- i. If yes is the test performed in accordance with manufactures directions?  Yes  No  unknown
- j. Is a record of the date, time, name of person performing the test and results of the drinking water sample kept?  Yes  No

## TANK AND PIPING DETAILS

### *Tank Room*

Is there a water tank?  Yes  No Details:

Where is it located?

Comments: ON 2ND FLOOR OF THE BUILDING

Is the room in which the water tank is located heated to maintain an optimum temperature of 4°C for stored water?

YES  NO

Comments: \_\_\_\_\_

Are there windows in the add-on that may allow direct sunlight onto the water holding tank? YES

NO

Comments: \_\_\_\_\_

Are there other heat sources near the tank? YES  NO

Comments: \_\_\_\_\_

Is there waterproof flooring with a sealed base to contain spills?  YES  NO

Comments: \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## Overall Tank

What are the tank size and dimensions?

3 x 6'6"  $\varnothing$  x 5' APPROX 1000 GALLONS

What material is the tank constructed of? FIBRE GLASS.

Is tank and associated piping constructed of safe materials (i.e. CSA approved and material that does not affect the taste of the water)?  YES  NO

Comments: \_\_\_\_\_

## Tank Inlet, Outlet and Lid

Is there adequate access on the tank for cleaning (i.e. min 15" access lid)?  YES  NO

Does the lid have a tight seal and is it watertight when closed?  YES  NO

Does the tank have an overflow or high level whistle?  YES  NO

Is the water tank drain accessible?  YES  NO

## WATER TANK AND WATER QUALITY CONDITION

Are there signs of staining or biofouling? YES  NO

Comments: TANKS ARE CLOSED

Is there any sediment or scum in bottom of tank? YES  NO

Comments: NOT AVAILABLE

Is there any odour associated with the water or tank? YES  NO

Have there been any bacteriological analyses conducted previously? YES  NO

Does the tank appear that it has been cleaned recently? YES  NO

Are the tanks easily assessed for the purpose of cleaning and disinfection? YES  NO

# **EBA Engineering Consultants Ltd.**

Creating and Delivering Better Solutions

## **8. Conclusions**

### a. Comments on overall installation:

THIS IS AN ACCEPTABLE INSTALLATION, WITH THE EXCEPTION OF A DOUBLE CHECK VALVE ASSEMBLY BETWEEN THE DOMESTIC SUPPLY AND THE FIRE WATER STORAGE TANK

### b. Recommendations:

INSTALL A DOUBLE CHECK VALVE ASSEMBLY IN PLACE OF THE 4" PVC CHECK VALVE. INITIATE A FREE CHLORINE RESIDUAL TESTING PROGRAM AT REGULAR INTERVALS. ASSURE FREE CHLORINE RESIDUAL IS MAINTAINED AT A MINIMUM OF 0.4 MG/L





Midnight Sun Drilling Co. Ltd.  
# 13 MacDonald Rd.  
Whitehorse, Yukon Y1A 4L1  
Phone: (403) 633-3070  
Fax: (403) 633-5758

FAX TRANSMITTAL

TO: ED MURPHY DATE: Nov 4/92 TIME: \_\_\_\_\_

COMPANY: MURPHY CONST. ADDRESS: \_\_\_\_\_

FROM: DAVID JAMIESON FAX #: 993-5076

# of pages including cover: \_\_\_\_\_

NOTE: if the transmission is incomplete or if you have any questions please contact the writer via Fax or Phone.

MESSAGE:

ED: ENCLOSURE

(1) SKETCH OF WELL

(2) DRAIN LOG OF HOLE

(3) PUMP MODEL



(4) ENVIRONMENTAL HEALTH REPORT

(5) CHEMICAL ANALYSIS OF WATER

(6) WELL YIELD TEST

(7) RECOVERY TEST

(8) GRAPH OF (6) AND (7)








# Midnight Sun Drilling Co. Ltd.

E Nov 3/92

PAGE NO \_\_\_\_\_

SUBJECT Water Well Rock Creek Fire Hall





# Midnight Sun Drilling Co. Ltd.


DATE Nov 3/92

PAGE NO \_\_\_\_\_

PROJECT MONARCH CONSTRUCTION ROCK CREEK FIREHALL

Pump

- 1/2 H.P. 230 VOLT SK10B5E-5P MONARCH  
Pump Suction 5m AT 3A'





ENVIRONMENTAL HEALTH SERVICES  
MEDICAL SERVICES BRANCH  
100, 300 MAIN STREET  
WHITEHORSE, YUKON Y1A 2B5

TELEPHONE 667-3938  
FAX 668-5726

Your file Votre référence

Our file Notre référence

Aqua Tech Supplies & Serv.  
123 Copper Rd  
Whitehorse, Y.T.  
Y1A 2Z7

Sept 16, 1992

Dear Sir:

An analysis of your water sample has been completed to assess the microbiological safety in accordance with the "Guidelines for Canadian Drinking Water Quality". The indicator organisms tested for are total coliforms and faecal coliforms. Total coliform (TC) bacteria are common in the environment; whereas, faecal coliform (FC) bacteria are only present in the gastrointestinal tract and faeces of warm blooded animals and humans.

RESULTS	DATE OF SAMPLE	LOCATION	TOTAL	FAECAL
	Sep 13/92	Rock Creek Fire Hall	Nil	Nil

**EXPLANATION OF RESULTS** - "X" indicates the category of your water.

Coliform Count

Interpretation

Less than 2 TC  
& NIL FC


The sample satisfied the criteria as outlined in the above mentioned Guidelines.

Information on disinfection is attached  Yes  No.

Please contact us with any questions regarding these results or any other concerns.

Technician: *Stuts*

Canada





WESTERN INDUSTRIAL LABORATORIES LIMITED

LABORATORY REPORT

Telephone (403) 439-7969 433-6362

8109 - 102 Street Edmonton, Alberta T6E 4A4

CHEMICAL ANALYSIS OF WATER

Submitted by Aquatech Supplies & Services Ltd.

Date 14 October 1992

Sample Rock Creek Fire Hall

Report No. 500-81

Received: 15 September 1992

Lab No. 92-2848

Table with 4 columns: Constituent, mg/L, Constituent, mg/L. Rows include Total Dissolved Solids (176), Fixed Dissolved Solids (118), Sodium (2.3), Calcium Ca (37), Magnesium Mg (9), Total Hardness as CaCO3 (129), Carbonate CO3 (nfi), Bicarbonate HCO3 (104), Total Alkalinity as CaCO3 (85), Sulfate SO4 (46), Chloride Cl (4), Iron Fe Dissolved (<0.05), Fluoride F (0.10), Nitrate + Nitrite N (<0.2), Manganese Mn (0.034), Total Kjeldahl Nitrogen (0.1), Ammonia Nitrogen (<0.1), Total Phosphate (<0.5).

pH 7.18 Conductivity 264 micromhos/cm Turbidity 4.6 NTU.

Remarks Colour (TCU) <5 Zinc (Zn) 0.012 mg/L Lead (Pb) <0.010 mg/L

Phenol <0.001 mg/L Total Sulphide <0.05 mg/L Copper (Cu) 0.005 mg/L

Arsenic (As) <0.0002 mg/L Mercury (Hg) <0.0001 mg/L


Iron Bacteria: A microscopic slide was prepared and stained for iron bacteria.

There were no iron bacteria observed when examined under the microscope.

NOTE: The Dissolved Iron was run on a portion of sample that had been passed through a 0.45 micron millipore filter.

WESTERN INDUSTRIAL LABORATORIES LIMITED

J. D. Haz F. D. Haz




*Murphy Construction*

Well Yield Test Data Rockcreek Firehall Water Well 1-92  
Rockcreek, Yukon

Time Test Started: Aug. 1, 1992 11:00AM

Time (min)	Flow (gpm)	DTW (m)	Total Flow	Drawdown (m)
0	10.3	1.75	0	
1	10.1	2.5	10	-0.75
2	10.2	2.535	20	-0.785
3	10.3	2.55	31	-0.8
4	10.2	2.56	41	-0.81
6	10.2	2.565	61	-0.815
8	10.2	2.565	82	-0.815
10	10.3	2.565	102	-0.815
13	10.3	2.565	133	-0.815
16	10.1	2.575	164	-0.825
20	10.2	2.58	204	-0.83
25	10.3	2.585	256	-0.835
32	10.4	2.59	328	-0.84
40	10.5	2.59	410	-0.84
50	10.5	2.59	514	-0.84
64	10.4	2.59	658	-0.84
80	10.5	2.595	824	-0.845
100	10.5	2.595	1031	-0.845
120	10.6	2.595	1239	-0.845
150	10.4	2.595	1549	-0.845
180	10.5	2.595	1860	-0.845
210	10.5	2.6	2172	-0.85
240	10.5	2.6	2483	-0.85
300	10.5	2.6	3107	-0.85
360	10.5	2.6	3735	-0.85

# ROCKCREEK FIREHALL WELL TEST



Elapsed time since pump started (min)

..... Drawdown — Flow      ..... DTW (m)

 <p>2005/08/19</p>	 <p>2005/08/19</p>
<p><b>Photo 093:</b> 2592 Klondike Valley Fire Hall</p>	<p><b>Photo 096:</b> 2592 Water filling station.</p>
 <p>2005/08/19</p>	 <p>2005/08/19</p>
<p><b>Photo 236:</b> 2592 Chlorination system, flow meter, and associated plumbing.</p>	<p><b>Photo 237:</b> 2592 Jet pump and pressure tank.</p>