

WELL 2599
N 7102 051
E 583 201
DRILLERS REPORT
NO.: n/a

Parking

DAWSON GRADER
STATION
BLDG. #2599

Truck Wash
Area

Unknown
Waste


Used
Solvent

40m to
2 Envirotanks
& Pump Islands
w/ Tanks

Gravel

Vehicle
Parking

Dredge
Pond



SCALE 1:400


NOTES:
1. UTM COORDINATES OBTAINED WITH A HAND HELD GPS USING NAD83 SYSTEM AND ARE CONSIDERED TO BE ACCURATE TO 10.0 m, APPROXIMATELY.

30 m RADIUS FROM WATER WELL FOR CONSIDERATION OF PROXIMITY TO POTENTIAL CONTAMINANT SOURCES.

	DESIGNED BY: R. MARTIN DRAWN BY: J. BUYCK DATE: SEPT. 2005 SCALE: AS SHOWN PROJECT No.: 1260002.004 ACAD FILENAME: 004-NORTHERN_REGION	SMALL PUBLIC WATER SYSTEMS ASSESSMENT NORTHERN REGION
	CLIENT: GOVERNMENT OF YUKON HIGHWAYS & PUBLIC WORKS DAWSON GRADER STATION BUILDING # 2599 SITE LOCATION DIAGRAM WELL ID: 2599	REVISION ISSUE 0 FIGURE No. FIGURE 2599-A

No.	ISSUED FOR CLIENT REVIEW	DESCRIPTION	DATE	APPROVED	REVISION
0			DD/MM/YY	XXX	

LEGEND



EBA Engineering Consultants Ltd.

PROJECT SMALL PUBLIC WATER SYSTEMS ASSESSMENT
WESTERN REGION

CLIENT

Yukon
Highways and Public Works
Property Management Branch

TITLE

SCHEMATIC SYSTEM
LEGEND


DATE APRIL 2006

DWN. JSB

CHKD. RMM

FILE NO. 1260002

DRWG. LEGEND



DRAWING IS BASED UPON SCHEMATIC PROVIDED BY BERT ALBISSER OF AQUA TECH SUPPLIES AND SERVICES LTD.

		PROJECT SMALL PUBLIC WATER SYSTEMS ASSESSMENT NORTHERN REGION	
CLIENT 		TITLE WATER SYSTEM DISTRIBUTION/TREATMENT SCHEMATIC SYSTEM ID.: 2599 DAWSON GRADER STATION - DAWSON, YT.	
DATE	SEPT., 2005	FILE NO.	1260002.004
	DWN.	CHKD.	RMM
	JSB		
		DWG.:	FIGURE 2599-B

Northern Region – Dawson City Grader Station
Building # 2599

DISTRIBUTION & TREATMENT SYSTEM DATA

Item	Description	Manufacturer	Model	Part No.	Serial No.	Size
1	Sub Pump	N/A	N/A			4"
2	PRESSURE TANKS	CON-AIRE	SCA 220	X 2		
3	PRESSURE SWITCH	SQUARE D	FSG 2			
4	PRESSURE GAUGE	WINTERS	0-100	4"		
5	WATER SOFTENER	AQUA TECH	AQUA 9500			90K DUREX
6	RO. SYSTEM	AQUA TECH	U SELECT			22000 GPD
7	STORAGE TANK	N/A				
8	JET PUMP					
9	PRESSURE TANK					
10	INLINE FILTER					

TABLE 2599 - 1: SUMMARY OF BACTERIOLOGICAL RESULTS

Building #	Building Name	Number of Sampling Events	Time Period over which Sampling was Done	Any Positive Total Coliform Results? (yes or no)	Fraction of Positive Total Coliform Results vs. Total Sampling Events	Any positive E. Coli results? (yes or no)	Most Recent Sampling Event Available for EBA Review	Is Most Recent Result Positive?
2599	Dawson City Grader Station	8	Oct-04 to Jun-05	no	0/8	no	9-Jun-05	no



Table 2599 - 2: Water Quality Results

SOURCE:	Building 2599 - Dawson City Grader Station				GCDWQ Criteria		
Location/ Resident	Dawson City						
Address							
Treatment	Softener, filtration, reverse osmosis	None	Softener, filtration	Softener, filtration, reverse osmosis			
Disinfection	None						
Source of Water							
Purpose of Sampling	Base Line	Base Line	Additional Sampling	Additional Sampling			
Sample Location			faucet (Non-Potable)	Washroom			
Date Sampled	29-Sep-04	8-Jun-05	19-Aug-05	19-Aug-05	Lower	Upper Limit	
Physical Tests (ALS)					AO	MAC	AO
Colour (CU)	<5	8.5					15
Conductivity (uS/cm)		386					
Total Dissolved Solids	<1	243	<1.3				500
Hardness CaCO3	<0.9	185			AO >200 = poor, > 500 unacceptable ^A		
pH	6.14	7.96			6.5		8.5
Turbidity (NTU)	0.3	41.1	1.22			1	5
UV Absorbance			0.109				
% UV Transmittance			77.8				
Dissolved Anions (ALS)							
Alkalinity-Total CaCO3	<5	134					
Chloride Cl	<0.5	0.99					250
Fluoride F	<0.05	0.112				1.5	
Silicate SiO4			13.8				
Sulphate SO4	<0.2	72.7					500
Nitrate Nitrogen N	<0.1	<0.10				10	
Nitrite Nitrogen N	<0.05	<0.10				3.4	
Ammonia Nitrogen N							
Total Phosphate PO4			0.0159				
Total Metals (ALS)							
Aluminum T-Al	<0.005	0.092	<0.020			0.1	
Antimony T-Sb	<0.0002	<0.00050	<0.0010			0.006	
Arsenic T-As	0.0047	0.0864	0.047	0.00457		0.025	
Barium T-Ba	<0.001	0.165	<0.040			1	
Boron T-B	0.002	<0.10	<0.20			5	
Cadmium T-Cd	<0.00001	<0.00020	<0.00040			0.005	
Calcium T-Ca		48.7	<0.20				
Chromium T-Cr	<0.0005	<0.0020	<0.0040			0.05	
Copper T-Cu	0.259	0.0423	0.0097			1	
Iron T-Fe	<0.01	8.39	0.171				0.3
Lead T-Pb	0.0039	0.0174	<0.0020			0.01	
Magnesium T-Mg		15.3	<0.20				
Manganese T-Mn	<0.005	0.651	<0.0040				0.05
Mercury T-Hg		<0.00020	<0.00020			0.001	
Potassium T-K		0.81	172				
Selenium T-Se		<0.0010	<0.0020			0.01	
Sodium T-Na	<0.4	4.3	<2.0				200
Uranium T-U	<0.0005	0.00189	0.00084			0.02	
Vanadium T-V			<0.030				
Zinc T-Zn	0.019	0.134	<0.10				5
Dissolved Metals							
Aluminum D-Al			<0.020			0.1	
Antimony D-Sb			<0.0010			0.006	
Arsenic D-As			0.0441			0.025	
Barium D-Ba			<0.040			1.0	
Boron D-B			<0.20			5	
Cadmium D-Cd			<0.00040			0.005	
Calcium D-Ca			<0.20				
Chromium D-Cr			<0.0040			0.05	
Copper D-Cu			0.0138				1.0
Iron D-Fe			0.043				0.3
Lead D-Pb			<0.0020			0.01	
Magnesium D-Mg			<0.20				
Manganese D-Mn			<0.0040				0.05
Mercury D-Hg			<0.00020			0.001	
Potassium D-K			172				
Selenium D-Se			<0.0020			0.01	
Sodium D-Na			<2.0				200
Uranium D-U			0.0008			0.02	
Vanadium D-V			<0.030				
Zinc D-Zn			<0.10				5.0
Organic Parameters							
Tannin and Lignin			0.24				
Total Organic Carbon C			4.61				
Field Chemistry (EBA)							
pH			7.81	7.83	6.5		8.5
IDS (ppm)			267	3			500
EC (uS/cm)			535	6			
Temperature (°C)			1.1	17.2			
Free Available Chlorine							

Notes:

- A. Guidelines indicated for hardness are not CDWQG, rather they are general aesthetic guidelines - exceedences are indicated in yellow highlighting.
- italics and underline indicates exceedence of proposed MAC (ie. arsenic)
- Bold with Yellow highlighting** indicates exceedence of CDWQG Aesthetic Objective (AO)
- Bold Underline with Yellow highlighting** indicates exceedence of CDWQG MAC
- Results are expressed as milligrams per litre except for pH and Colour (CU)
- Conductivity (umhos/cm), Temperature (°C) and Turbidity (NTU)
- < = Less than the detection limit indicated.
- AO = Aesthetic Objective
- MAC = Maximum Acceptable Concentration (Health Based)



EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

SMALL PUBLIC WATER SYSTEM ASSESSMENT

PART A: EBA Site Inspection

Inspector: Ryan Martin, Luke Lebel

Date August 19, 2005

WELL ID #	Owner	Location Description
2599	YTG	Dawson City Grader Station

1. Well Location and Potential Contaminant Sources

a. General location of well: (Community, Subdivision, etc.)

Dawson City

b. Specific location: (Road or street, Building number, name of owner and/, legal description,

Klondike Highway

c. GPS location: N 7102051 E 583201 elev 343m ±10m

d. Is there electric power? Yes No

e. Is there outside water access? Yes No

f. Does the well system have:

15 or more service connections to a piped distribution system? If so how many _____

Grader station

5 or more delivery sites on a trucked distribution system? If so how many _____

g. Nearest building, specify Grader station

h. Distance from well to building ~6m

i. If there is an effluent disposal field, is its location known? Yes No

j. Distance from well to nearest point of known field: 50 m

k. Well location relative to field: upslope downslope lateral

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

l. Is there any part of a sewage disposal system(s) or other potential sources of pollution that may pose a health and safety risk within 30 m? Yes No

Tank @ ~42m, Rock pits @ ~36m

m. Is the well located within 300 m from a sewage lagoon or pit? Yes No unlikely

n. Is the well located within 120 m from a solid waste site or dump, cemetery? Yes No unlikely

o. Is the infrastructure protecting the wellhead, pumphouse, storage tank and/or water treatment plant designed and secured to prevent:

Unauthorized access by humans? Yes No
Unlocked enclosure

Entrance by animals? Yes No
Access possible, but unlikely

p. Is well site subject to flooding? Yes No

q. Is the well site well drained? Yes No

r. Is there a buried fuel tank on the property? Yes No

If yes, is it in use abandoned

Is the location known? Yes No

Distance from the well to known buried tank _____

s. Are there any other known contaminant sources on the property?

Yes No Describe _____

If yes, specify the source: dump sewage lagoon cemetery other

Potential Source 1: ASTs; Distance from well to Potential Source 1: ~44m

Potential Source 2: Fueling station; Distance from well to Potential Source 2: ~74m

Potential Source 3: Drums; Distance from well to Potential Source 3: ~33m

Potential Source 4: Oil/water separator; Distance from well to Potential Source 4: ~40m

t. Are there other wells on this property? Yes No unlikely

How many? _____ in use abandoned require proper sealing

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

2. Well and Wellhead information:

- a. When was well installed? Year unknown Month _____
- b. Type: drilled dug sand point other _____
- c. Is there a drillers log for the well: Yes No
- d. Is there a surface seal to 6 m Yes No unknown unlikely
- e. Surface casing: Yes Diameter _____ No
- f. Well casing: Diameter 15 cm Material: steel plastic concrete
- g. Depth of well: unknown measured (if possible) reported from log
- h. Static water level below ground: unknown
 measured (if possible) reported from log flowing
- i. (If granular) Is the well completed: open end casing with a well screen
 with slotted pipe unknown other unknown
- j. (If bedrock) Does the well have a liner? yes No steel plastic
- k. If there is a well screen: length _____ slot size(s) _____
Location of screen: from _____ to _____ from log reported
- l. Is there a sump below the screen? Yes No unknown
- m. Is the well head: in pumphouse in pit pitless adaptor in a building
 in a wooden enclosure other, describe _____
- n. If the well head is located in a wooden enclosure,

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- i. Is the well head below grade? describe in detail ~ 2.3 m below grade
- ii. Are there signs of ponding on the enclosure(e.g. water stains, etc.)? Yes No
- iii. Is the wellhead enclosed by fiberglass insulations? Yes No
- iv. Any evidence of rodents? Specify No.
- v. Does the well casing have a proper seal cap? Yes No
If no, describe condition Split gasket cap

3. Water Supplying This Well:

- a. By definition is the water from a surface water source or under the direct influence of surface water?
 Yes No farther investigation required.

If yes is there treatment or disinfection Yes No

Explain (filtration, disinfection etc...) softener for regular water + RO for drinking water

4. Aquifer Supplying This Well:

- a. The aquifer is: bedrock granular sediment unknown
likely
- b. Does water level and/or well capacity show seasonal fluctuation? Yes No
unlikely

5. Pump Installation:

- a. Is the well equipped with a pump? yes No
- b. Type of pump: hand electric submersible jet
 shallow well centrifugal other, _____
- c. Description: Manufacturer _____ Model _____
horsepower _____ capacity _____ voltage _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

d. Date installed: _____ By: _____

e. For submersible pump, depth of setting below surface _____

f. Drop pipe for submersible pump: steel plastic *unknown*

g. Pump delivers water to: pressure tank elevated tank other

h. Are there automatic pump controls: Yes No

i. Is there provision for taking water samples before water reaches storage? Yes No
But tap against floor

j. Is there a water meter on the system? Yes No

k. Is the pump and piping protected from freezing? Yes No

If yes, describe: Styrofoam insulation + heat trace

l. Comments on pump installation: _____

6. Conclusions

a. Comments on overall installation:

b. Recommendations: _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

PART B: EBA Site Inspection

Inspector: BERT ALBISSER

Date AUG 19/05

WELL ID #	Owner	Location Description
<u>2599</u>	<u>YTG</u>	

6. Water Treatment

a. Is well water treated? Yes No; Type of treatment:

chlorination iron and or manganese removal other REVERSE OSMOSIS

b. Is water entering plumbing or piped distribution system treated with chlorine or another treatment that is as effective as chlorine used to achieve disinfection throughout the system?

Yes No If so how _____

c. If treated with chlorine, is the free residual chlorine concentration less than 0.2 mg/L

Yes No _____ reading.

Tested at _____ (location)

d. Is testing for chlorine residual concentration done at the tap (eg. Kitchen faucet) or from representative points in a piped distribution system, including a point from tap at the end line

Yes No If yes how often? _____

e. If the drinking water is being transported by water delivery truck does it have a minimum chlorine free residual of 0.4 mg/L at the time of fill. Yes No

7. Water Quality (observations):

a. Does the water stain plumbing? yes No slight severe

Type of stain: brown red black

b. Does the water contain sediment? Yes No occasional constant

c. Is there an unpleasant odour? Yes No H₂S Other _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- d. Is there an unpleasant taste? Yes No brackish Other _____
- e. Is there a history of bad bacterial analyses? Yes No
- f. Is there a chemical analysis? Yes No adequate incomplete
- g. Is there analysis of trihalomethanes (THMs) where the water source is a surface water supply or a well under the direct influence of surface water? Yes No
- h. Is the drinking water tested daily with an accurate reading chlorine test kit capable of reading in the range 0 to 3.5 mg/L of free chlorine residual in increments of 0.1mg/L? Yes No unknown
- i. If yes is the test performed in accordance with manufactures directions? Yes No unknown
- j. Is a record of the date, time, name of person performing the test and results of the drinking water sample kept? Yes No

TANK AND PIPING DETAILS

Tank Room

Is there a water tank? Yes No Details: PRESSURE TANKS & R.O. WATER STORAGE TANK

Where is it located? RO TANK UNDER REAR STAIRWELL
Comments: PRESSURE TANKS UNDER FRONT STAIRWELL

Is the room in which the water tank is located heated to maintain an optimum temperature of 4°C for stored water?

YES NO

Comments: _____

Are there windows in the add-on that may allow direct sunlight onto the water holding tank? YES

NO

Comments: _____

Are there other heat sources near the tank? YES NO

Comments: _____

Is there waterproof flooring with a sealed base to contain spills? YES NO

Comments: _____

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

Overall Tank

What are the tank size and dimensions?

What material is the tank constructed of? FIBRE GLASS

Is tank and associated piping constructed of safe materials (i.e. CSA approved and material that does not affect the taste of the water)? YES NO

Comments: _____

Tank Inlet, Outlet and Lid

Is there adequate access on the tank for cleaning (i.e. min 15" access lid)? YES NO

Does the lid have a tight seal and is it watertight when closed? YES NO

Does the tank have an overflow or high level whistle? YES NO

Is the water tank drain accessible? YES NO

WATER TANK AND WATER QUALITY CONDITION

Are there signs of staining or biofouling? YES NO

Comments: _____

Is there any sediment or scum in bottom of tank? YES NO

Comments: _____

Is there any odour associated with the water or tank? YES NO

Have there been any bacteriological analyses conducted previously? YES NO ?

Does the tank appear that it has been cleaned recently? YES NO

Are the tanks easily assessed for the purpose of cleaning and disinfection? YES NO

EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

8. Conclusions

a. Comments on overall installation:

THIS INSTALLATION IS IN GOOD ORDER

b. Recommendations:

INSTALL FILTRATION AND UV SYSTEM (WFF-55)
ON DOMESTIC LOOP.



Photo 087: 2599 Wellhead enclosure.



Photo 086: 2599 Wellhead in pit.



Photo 230: 2599 Pressure tank, pump controls and softener system.



Photo 234: 2599 Reverse osmosis system (front) water storage tank (back)