

**NOTES:**

1. UTM COORDINATES OBTAINED WITH A HAND HELD GPS USING NAD83 SYSTEM AND ARE CONSIDERED TO BE ACCURATE TO 10.0 m, APPROXIMATELY.



30 m RADIUS FROM WATER WELL FOR CONSIDERATION OF PROXIMITY TO POTENTIAL CONTAMINANT SOURCES.

| No. | DESCRIPTION              | DATE     | APPROVED |
|-----|--------------------------|----------|----------|
| 0   | ISSUED FOR CLIENT REVIEW | DD/MM/YY | XXX      |
|     | REVISION                 |          |          |



**EBA Engineering Consultants Ltd.**

DESIGNED BY: R. MARTIN  
 DRAWN BY: J. BUYCK  
 DATE: JUNE 2005  
 SCALE: AS SHOWN  
 PROJECT No.: 1260002.001  
 ACAD FILENAME: 00FRASER-CAMP-DESIGN

CLIENT:



Highways and Public Works  
 Property Management Branch


SMALL PUBLIC WATER SYSTEMS ASSESSMENT  
 WHITEHORSE REGION

GOVERNMENT OF YUKON  
 HIGHWAYS & PUBLIC WORKS

FRASER CAMP  
 SITE 1500  
 SITE LOCATION DIAGRAM

|             |              |
|-------------|--------------|
| REVISION    | ISSUE        |
|             | 0            |
| DRAWING No. | FIGURE 1500A |





SCHEMATIC PRODUCED BY BERT ALBISSER OF AQUA TECH SUPPLIES & SERVICES LTD.



**EBA Engineering Consultants Ltd.**

PROJECT

SMALL PUBLIC WATER SYSTEMS ASSESSMENT  
WHITEHORSE REGION

CLIENT



Highways and Public Works  
Property Management Branch

TITLE

WATER SYSTEM DISTRIBUTION/TREATMENT  
SCHEMATIC SYSTEM ID.: 1500  
FRASER CAMP

DATE APRIL 2006

DWN. JSB

CHKD. RMM

FILE NO. 1260002.001

DWG.: FIGURE 1500B

Whitehorse Region – Fraser Camp  
Building # 1500

DISTRIBUTION & TREATMENT SYSTEM DATA

| Item | Description            | Manufacturer | Model         | Part No. | Serial No.      | Size        |
|------|------------------------|--------------|---------------|----------|-----------------|-------------|
| 1    | PRESSURE CONTROL       | WATTS        | BUAG25        |          |                 | 2"          |
| 2    | PRIMARY FILTER         | HARMSCO      | ST-BC-8       | PD-10-20 | 156066-06-07-01 | 2" x 20"    |
| 3    | SECONDARY FILTER       | HARMSCO      | ST-BC-8       | PD-10-20 | 156066-06-07-01 | 2" x 20"    |
| 4    | CHLORINE INJECTION     | LMI          | A771-35851    |          | HYZ3638649      | 3/8"        |
| 5    | FLOWMETER PULSER       | LMI          | RFP-20        |          |                 |             |
| 6    | CHLORINE SOLUTION TANK | LMI.         | 30 GALLON     |          |                 | 30 GALLON   |
| 7    | WATER TANK.            |              | AG1250        |          |                 | 1250 GALLON |
| 8    | JET PUMP.              | MONARCH      | JKS-54        |          | 9004            | 1HP.        |
| 9    | PRESSURE TANK.         | THERMEX      | JOB #<br>7341 |          | C REG E 8463-1  | 600 GALLON  |
| 10   |                        |              |               |          |                 |             |

**TABLE 1500 - 1: SUMMARY OF BACTERIOLOGICAL RESULTS**

| <b>Building #</b> | <b>Building Name</b> | <b>Number of Sampling Events</b> | <b>Time Period over which Sampling was Done</b> | <b>Any Positive Total Coliform Results? (yes or no)</b> | <b>Fraction of Positive Total Coliform Results vs. Total Sampling Events</b> | <b>Any positive E.Coli results? (yes or no)</b> | <b>Most Recent Sampling Event Available for EBA Review</b> | <b>Is Most Recent Result Positive?</b> |
|-------------------|----------------------|----------------------------------|---|---|--|---|--|--|
| 1500              | Fraser Camp          | 6                                | Sept-04 to Mar-05                               | yes   | 1/6  | no  | 2-Mar-05   | no                                     |



**Table 1500-2: Water Quality Results**

| SOURCE:                       |  | Building 1500 - Fraser Camp                        |                                  | GCDWQ Criteria                                  |             |      |
|-------------------------------|--|--|----------------------------------|---|-------------|------|
| Location/ Resident            |  | Fraser   |                                  |   |             |      |
| Address                       |  |  |                                  |   |             |      |
| Treatment                     |  | Chlorination and Filtration                        |                                  |   |             |      |
| Source of Water               |  | Fraser Lake, Microhydroelectric Generating Station |                                  |   |             |      |
| Purpose of Sampling           |  | Baseline   | Additional Sampling              |   |             |      |
| Sample Location               |  |  | Laundry Sink Tap in Truck Garage |   |             |      |
| Date Sampled                  |  |  | 11-May-05                        | Lower Limit                                     | Upper Limit |      |
| Physical Tests (ALS)          |  |  |                                  | AO  | MAC         | AO   |
| Colour (CU)                   |  | <5.0   |                                  |   |             | 15   |
| Conductivity (uS/cm)          |  | 43.2   |                                  |   |             |      |
| Total Dissolved Solids        |  | 22   |                                  |   |             | 500  |
| Hardness CaCO3                |  | 19.8   |                                  | AO >200 = poor, > 500 unacceptable <sup>A</sup> |             |      |
| pH                            |  | 7.71   |                                  | 6.5   |             | 8.5  |
| Turbidity (NTU)               |  | 0.14   |                                  |   | 1           | 5    |
| <b>Dissolved Anions (ALS)</b> |  |  |                                  |   |             |      |
| Alkalinity-Total CaCO3        |  |  |                                  |   |             |      |
| Chloride Cl                   |  | <0.50  |                                  |   |             | 250  |
| Fluoride F                    |  | 0.105  |                                  |   | 1.5         |      |
| Sulphate SO4                  |  | 2.28   |                                  |   |             | 500  |
| Nitrate Nitrogen N            |  | <0.10  |                                  |   | 10          |      |
| Nitrite Nitrogen N            |  | <0.10  |                                  |   | 1           |      |
| <b>Total Metals (ALS)</b>     |  |  |                                  |   |             |      |
| Aluminum T-Al                 |  | <0.010   |                                  |   |             |      |
| Antimony T-Sb                 |  | <0.00050   |                                  |   | 0.006       |      |
| Arsenic T-As                  |  | <0.00010   |                                  |   | 0.025       |      |
| Barium T-Ba                   |  | <0.020   |                                  |   | 1           |      |
| Boron T-B                     |  | <0.10  |                                  |   | 5           |      |
| Cadmium T-Cd                  |  | <0.00020   |                                  |   | 0.005       |      |
| Calcium T-Ca                  |  | 6.77   |                                  |   |             |      |
| Chromium T-Cr                 |  | <0.0020  |                                  |   | 0.05        |      |
| Copper T-Cu                   |  | 0.277  |                                  |   | 1           |      |
| Iron T-Fe                     |  | 0.035  |                                  |   |             | 0.3  |
| Lead T-Pb                     |  | <0.0010  |                                  |   | 0.01        |      |
| Magnesium T-Mg                |  | 0.71   |                                  |   |             |      |
| Manganese T-Mn                |  | <0.0020  |                                  |   |             | 0.05 |
| Mercury T-Hg                  |  | <0.00020   |                                  |   | 0.001       |      |
| Potassium T-K                 |  | 0.28   |                                  |   |             |      |
| Selenium T-Se                 |  | <0.0010  |                                  |   | 0.01        |      |
| Sodium T-Na                   |  | <2.0   |                                  |   |             | 200  |
| Uranium T-U                   |  | 0.00103  |                                  |   | 0.02        |      |
| Zinc T-Zn                     |  | <0.050   |                                  |   |             | 5    |
| <b>Trihalomethanes</b>        |  |  |                                  |   |             |      |
| Bromodichloromethane          |  | <0.0010  |                                  |   |             |      |
| Bromoform                     |  | <0.0010  |                                  |   |             |      |
| Chloroform                    |  | <0.0010  |                                  |   |             |      |
| Dibromochloromethane          |  | <0.0010  |                                  |   |             |      |
| Total Trihalomethanes         |  | <0.0040  |                                  |   | 0.1         |      |
| <b>Haloacetic Acids</b>       |  |  |                                  |   |             |      |
| Bromoacetic Acid              |  | <0.0020  |                                  |   |             |      |
| Bromochloroacetic Acid        |  | <0.0020  |                                  |   |             |      |
| Chloroacetic Acid             |  | <0.020   |                                  |   |             |      |
| Dibromoacetic Acid            |  | <0.0020  |                                  |   |             |      |
| Dichloroacetic Acid           |  | <0.0020  |                                  |   |             |      |
| Trichloroacetic Acid (TCA)    |  | <0.0020  |                                  |   |             |      |
| <b>Field Chemistry (EBA)</b>  |  |  |                                  |   |             |      |
| pH                            |  | 8.27   |                                  | 6.5   |             | 8.5  |
| TDS                           |  | 17   |                                  |   |             | 500  |
| EC (uS/cm)                    |  | 37   |                                  |   |             |      |
| Temperature                   |  | 8.1  |                                  |   |             |      |
| Free Available Chlorine       |  | 0.01   |                                  |   |             | 250  |

**Notes:**

A. Guidelines indicated for hardness are not CDWQG, rather they are general aesthetic guidelines - exceedences are indicated in yellow highlighting.

Shading indicates exceedence of Proposed MAC guideline (arsenic).

**Bold Underline with Yellow shading** indicates exceedence of CDWQG MAC

Results are expressed as milligrams per litre except for pH and Colour (CU), Conductivity (umhos/cm), Temperature (°C) and Turbidity (NTU)

< = Less than the detection limit indicated.

AO = Aesthetic Objective

MAC = Maximum Acceptable Concentration (Health Based)



**Table 1500-3: Summary of Well Assessment Results  
SMALL PUBLIC DRINKING WATER SYSTEMS**

| <b>Well Identification and Location</b> |                      |                 |                                |                               |   |
|---|----------------------|-----------------|--------------------------------|-------------------------------|---|
| <b>Building #</b>                       | <b>Building Name</b> | <b>Location</b> | <b>Northing<br/>(+/- 10 m)</b> | <b>Easting<br/>(+/- 10 m)</b> | <b>Grade<br/>Elevation<br/>(+/- 10 m)</b> |
| 1500                                    | Fraser Camp          | Fraser          | 6619679                        | 497323                        | 848                                       |



**Table 1500-4: Potential Contaminant Sources  
Building 1500 – Fraser Camp**

| <b>Potential Contaminant Source</b>          | <b>Potential Contaminants</b>   | <b>Distance from Water Source</b>           | <b>Northi<br/>ng</b> | <b>Easting</b> |
|--|---|---|----------------------|----------------|
| Dump or Landfill                             | <i>Organic</i> and inorganic chemicals.   | >>120 m                                     |                      |                |
| Cemetery                                     | <i>Biological</i> <sup>1</sup> , inorganic <sup>2</sup> and organic parameters. | >>120 m                                     |                      |                |
| Sewage lagoon                                | <i>Biological</i> , inorganic and organic parameters.                           | >>300 m                                     |                      |                |
| Sewage lines and lift stations               | <i>Biological</i> , inorganic and organic parameters.                           | >>30 m                                      |                      |                |
| Septic tanks and fields                      | <i>Biological and Inorganic</i> parameters.                                     | >>30 m                                      |                      |                |
| Gas stations                                 | <i>Organic and Inorganic</i> parameters.  | >>30 m                                      |                      |                |
| Undergrounds Fuel Storage Tanks (USTs)       | <i>Organic</i> parameters.  | >>30 m                                      |                      |                |
| Above ground storage tanks (ASTs)            | <i>Organic parameters.</i>  | >>30 m                                      |                      |                |
| Naturally occurring sources of contamination | <i>Radionuclides, Bacteria and Viruses from surfacewater sources.</i>           | Water system utilizes surface water source. |                      |                |

**Notes:**

*Bold highlighting of distances indicates non-compliance with proposed guidelines*

1- Biological parameters include: bacteria, viruses, protozoa (parasitic organisms), helminthes (intestinal worms), and bio aerosols (inhalable moulds and fungi).

2 – Inorganic contaminants could include arsenic in embalming chemicals (prior to early 1900's), and heavy metals in caskets.

**Required Setback Distances Draft Guidelines for Part III – Small Public Drinking Water Systems:**

300 m (1,000 ft) from a sewage lagoon or pit and manure heaps

120 m (400 ft) from a solid waste dump or a cemetery

30 m (100 ft) from any other potential source of contamination

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## SMALL PUBLIC WATER SYSTEM ASSESSMENT

### PART A: EBA Site Inspection

Inspector: Ryan Mardin  
Luke Lebel

Date May 11, 2009

| WELL ID # | Owner | Location Description |
|-----------|-------|----------------------|
| 1500      | YTG   | Fraser Camp          |

#### 1. Well Location and Potential Contaminant Sources

a. General location of well: (Community, Subdivision, etc.)

Fraser

b. Specific location: (Road or street, Building number, name of owner and/, legal description,

Fraser Camp, Alaska Highway, Whitepass Summit

c. GPS location: 497323 Easting; 6619679 Northing; 848m elev., ± 7m

d. Is there electric power?  Yes  No

e. Does the well system have: The water is piped from surface water source in a nearby lake

15 or more service connections to a piped distribution system? If so how many \_\_\_\_\_  
Services maintenance camp, customs, and residences

5 or more delivery sites on a trucked distribution system? If so how many \_\_\_\_\_

f. Nearest building, specify Any building is >>60m away from the surface water source

g. Distance from well to building \_\_\_\_\_

h. If there is an effluent disposal field, is its location known?  Yes  No

i. Distance from well to nearest point of known field: It is <sup>very</sup> unlikely that there is an effluent disposal field within 150m of the water source

j. Well location relative to field:  upslope  downslope  lateral

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

k. Is there any part of a sewage disposal system(s) or other potential sources of pollution that may pose a health and safety risk within 30 m?  Yes  No

l. Is the well located within 300 m from a sewage lagoon or pit?  Yes  No

m. Is the well located within 120 m from a solid waste site or dump, cemetery?  Yes  No

n. Is the infrastructure protecting the wellhead, pumphouse, storage tank and/or water treatment plant designed and secured to prevent:

Unauthorized access by humans?  Yes  No Entrance by animals?  Yes  No

o. Is well site subject to flooding?  Yes  No

p. Is the well site well drained?  Yes  No

q. Is there a buried fuel tank on the property?  Yes  No

If yes, is it  in use  abandoned

Is the location known?  Yes  No

Distance from the well to known buried tank \_\_\_\_\_

r. Are there any other known contaminant sources on the property?

*unlikely anywhere near the water source*

Yes  No Describe \_\_\_\_\_

If yes, specify the source:  dump  sewage lagoon  cemetery  other

Potential Source 1: \_\_\_\_\_; Distance from well to Potential Source 1: \_\_\_\_\_

Potential Source 2: \_\_\_\_\_; Distance from well to Potential Source 2: \_\_\_\_\_

Potential Source 3: \_\_\_\_\_; Distance from well to Potential Source 3: \_\_\_\_\_

Potential Source 4: \_\_\_\_\_; Distance from well to Potential Source 4: \_\_\_\_\_

s. Are there other wells on this property?  Yes  No

How many? \_\_\_\_\_  in use  abandoned  require proper sealing

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## 2. Well and Wellhead information:

- a. When was well installed? Year \_\_\_\_\_ Month \_\_\_\_\_
- b. Type:  drilled  dug  sand point  other \_\_\_\_\_
- c. Is there a drillers log for the well:  Yes  No
- d. Is there a surface seal to 6 m  Yes  No  unknown  unlikely
- e. Surface casing:  Yes Diameter \_\_\_\_\_  No
- f. Well casing: Diameter \_\_\_\_\_ Material:  steel  plastic  concrete
- g. Depth of well: \_\_\_\_\_  measured (if possible)  reported  from log
- h. Static water level below ground: \_\_\_\_\_  
 measured (if possible)  reported  from log  flowing
- i. (If granular) Is the well completed:  open end casing  with a well screen  
 with slotted pipe  unknown other \_\_\_\_\_
- j. (If bedrock) Does the well have a liner?  yes  No  steel  plastic
- k. If there is a well screen: length \_\_\_\_\_ slot size(s) \_\_\_\_\_  
Location of screen: from \_\_\_\_\_ to \_\_\_\_\_ from log reported
- l. Is there a sump below the screen?  Yes  No
- m. Is the well head:  in pumphouse  in pit  pitless adaptor  in a building  
 in a wooden enclosure other, describe \_\_\_\_\_
- n. If the well head is located in a wooden enclosure,

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

- i. Is the well head below grade? describe in detail \_\_\_\_\_
- ii. Are there signs of ponding on the enclosure(e.g. water stains, etc.)?  Yes  No
- iii. Is the wellhead enclosed by fiberglass insulations?  Yes  No
- iv. Any evidence of rodents? Specify \_\_\_\_\_
- v. Does the well casing have a proper seal cap?  Yes  No

If no, describe condition \_\_\_\_\_

### 3. Water Supplying This Well:

- a. By definition is the water from a surface water source or under the direct influence of surface water?

Yes  No  farther investigation required.  
The water is taken directly from a surface water source  
If yes is there treatment  Yes  No

Explain (filtration, disinfection etc...) LMI proportional feed chlorinator

### 4. Aquifer Supplying This Well:

- a. The aquifer is:  bedrock  granular sediment  unknown  
The water is directly from a surface water source
- b. Does water level and/or well capacity show seasonal fluctuation?  Yes  No

### 5. Pump Installation:

- a. Is the well equipped with a pump?  yes  No
- b. Type of pump:  hand  electric submersible  jet  
 shallow well centrifugal  other, \_\_\_\_\_
- c. Description: Manufacturer \_\_\_\_\_ Model \_\_\_\_\_  
horsepower \_\_\_\_\_ capacity \_\_\_\_\_ voltage \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

d. Date installed: \_\_\_\_\_ By: \_\_\_\_\_

e. For submersible pump, depth of setting below surface \_\_\_\_\_

f. Drop pipe for submersible pump:  steel  plastic

g. Pump delivers water to:  pressure tank  elevated tank  other

h. Are there automatic pump controls:  Yes  No

i. Is there provision for taking water samples before water reaches storage?  Yes  No

j. Is there a water meter on the system?  Yes  No  
Combination flow meter pulser for the chlorination system  
RFP-20 2788800 Gal.(U.S.)

k. Is the pump and piping protected from freezing?  Yes  No  
unknown, likely

If yes, describe: \_\_\_\_\_

l. Comments on pump installation: \_\_\_\_\_

## 6. Conclusions

a. Comments on overall installation:

This system is not from a well, but is rather from a surface body of water, Fraser Lake. The water is piped down to run a hydroelectric generating station, and water is taken from that to supply the system. There is a LMI proportional feed chlorinator used to treat the water.

b. Recommendations: \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## PART B: EBA Site Inspection

Inspector: \_\_\_\_\_

Date \_\_\_\_\_

| WELL ID # | Owner | Location Description    |
|-----------|-------|-------------------------|
| 1500      | YTG   | FRASER MAINTENANCE CAMP |

### 6. Water Treatment

*PENSTOCK FEED*

a. Is well water treated?  Yes  No; Type of treatment:

chlorination  iron and or manganese removal  other \_\_\_\_\_

b. Is water entering plumbing or piped distribution system treated with chlorine or another treatment that is as effective as chlorine used to achieve disinfection throughout the system?

Yes  No If so how \_\_\_\_\_

c. If treated with chlorine, is the free residual chlorine concentration less than 0.2 mg/L

Yes  No .01 reading.

Tested at WATER ROOM TAP (location)

d. Is testing for chlorine residual concentration done at the tap (eg. Kitchen faucet) or from representative points in a piped distribution system, including a point from tap at the end line

Yes  No If yes how often? \_\_\_\_\_

e. If the drinking water is being transported by water delivery truck does it have a minimum chlorine free residual of 0.4 mg/L at the time of fill.  Yes  No *N/A*

### 7. Water Quality (observations):

a. Does the water stain plumbing?  yes  No  slight  severe

Type of stain:  brown  red  black

b. Does the water contain sediment?  Yes  No  occasional  constant

c. Is there an unpleasant odour?  Yes  No  H<sub>2</sub>S  Other \_\_\_\_\_

# **EBA Engineering Consultants Ltd.**

Creating and Delivering Better Solutions

- d. Is there an unpleasant taste?  Yes  No  brackish  Other \_\_\_\_\_
- e. Is there a history of bad bacterial analyses?  Yes  No
- f. Is there a chemical analysis?  Yes  No  adequate  incomplete
- g. Is there analysis of trihalomethanes (THMs) where the water source is a surface water supply or a well under the direct influence of surface water?  Yes  No
- h. Is the drinking water tested daily with an accurate reading chlorine test kit capable of reading in the range 0 to 3.5 mg/L of free chlorine residual in increments of 0.1mg/L?  Yes  No  unknown
- i. If yes is the test performed in accordance with manufactures directions?  Yes  No  unknown
- j. Is a record of the date, time, name of person performing the test and results of the drinking water sample kept?  Yes  No

## **TANK AND PIPING DETAILS**

### ***Tank Room***

Is there a water tank? Yes No Details:

Where is it located?

Comments: Water Room

Is the room in which the water tank is located heated to maintain an optimum temperature of 4°C for stored water?

YES  NO

Comments: OVERHEAD Forced Air unit

Are there windows in the add-on that may allow direct sunlight onto the water holding tank? YES

NO

Comments: \_\_\_\_\_

Are there other heat sources near the tank? YES  NO

Comments: \_\_\_\_\_

Is there waterproof flooring with a sealed base to contain spills?  YES  NO

Comments: \_\_\_\_\_

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## Overall Tank

What are the tank size and dimensions?

AG 1250

What material is the tank constructed of? FIBRE GLASS.

Is tank and associated piping constructed of safe materials (i.e. CSA approved and material that does not affect the taste of the water)?  YES  NO

Comments: TANK NEEDS CLEANING.

## Tank Inlet, Outlet and Lid

Is there adequate access on the tank for cleaning (i.e. min 15" access lid)?  YES  NO

Does the lid have a tight seal and is it watertight when closed? YES  NO

Does the tank have an overflow or high level whistle?  YES  NO

Is the water tank drain accessible?  YES  NO

## WATER TANK AND WATER QUALITY CONDITION

Are there signs of staining or biofouling? YES  NO

Comments: \_\_\_\_\_

Is there any sediment or scum in bottom of tank?  YES  NO

Comments: \_\_\_\_\_

Is there any odour associated with the water or tank? YES  NO

Have there been any bacteriological analyses conducted previously? YES  NO UNKNOWN

Does the tank appear that it has been cleaned recently? YES  NO

Are the tanks easily assessed for the purpose of cleaning and disinfection?  YES  NO

# EBA Engineering Consultants Ltd.

Creating and Delivering Better Solutions

## 8. Conclusions

a. Comments on overall installation:

THE SYSTEM HAS ALL THE NECESSARY COMPONENTS TO PROVIDE SAFE DRINKING WATER TO THE FACILITY.

b. Recommendations:

A REGULAR STORAGE TANK CLEANING SCHEDULE SHOULD BE INITIATED. CHLORINE RESIDUAL TESTING SHOULD BE SCHEDULED WITH PROPER RECORDS OF TEST RESULTS. THE LARGE PRESSURE TANK SHOULD BE FLUSHED WITH 200PPM CHLORINE SOLUTION ANNUALLY.



Environment  
Canada

Environnement  
Canada

**Enforcement and Emergencies Section**  
91782 Alaska Highway, Whitehorse, YT Y1A 5B7  
PH: 867.667.3400 FAX: 867.667.7962

## Spill Report Information

|                            |  |
|----------------------------|--|
| <b>Spill #</b>             | 7907   |
| <b>Jurisdiction</b>        | Yukon  |
| <b>Community</b>           | Fraser Camp  |
| <b>Address</b>             |  |
| <b>Highway</b>             |  |
| <b>Milepost</b>            |  |
| <b>Feature</b>             | Fraser Camp  |
| <b>Location and Cause</b>  | WPYR Pipeline - rupture caused by damage done by cat during snow removal operations  |
| <b>Latitude</b>            | 59.716667  |
| <b>Longitude</b>           | -135.066667  |
| <b>Incident Date</b>       | 4/27/1979 6:00:00 AM   |
| <b>Lead Agency</b>         | Environment Canada - Environmental Protection Service  |
| <b>Other Agency</b>        | Department of Indian Affairs and Northern Development  |
| <b>Company(s)</b>          | White Pass & Yukon Route   |
| <b>Amount</b>              | 41958  |
| <b>Units</b>               | Litres   |
| <b>Quantity</b>            | Estimate   |
| <b>Release Description</b> | Leaked   |
| <b>Additional Quantit</b>  |  |
| <b>Concentration</b>       |  |
| <b>Concentration Unit</b>  |  |
| <b>Phase</b>               | Liquid   |
| <b>Major Contaminant</b>   | Diesel   |
| <b>2nd Contaminant</b>     |  |
| <b>3rd Contaminant</b>     |  |
| <b>4th Contaminant</b>     |  |
| <b>Outcome</b>             | fuel spilled on ice surface of alpine lake - sorbent boom used and fuel pumped off - remaining burned - suggested contaminated snow be removed |



Environment  
Canada

Environment  
Canada

**Enforcement and Emergencies Section**  
91782 Alaska Highway, Whitehorse, YT Y1A 5B7  
PH: 867.667.3400 FAX: 867.667.7962

## Spill Report Information

|                            |  |
|----------------------------|--|
| <b>Spill #</b>             | 9036   |
| <b>Jurisdiction</b>        | Yukon  |
| <b>Community</b>           | Fraser Camp  |
| <b>Address</b>             |  |
| <b>Highway</b>             |  |
| <b>Milepost</b>            |  |
| <b>Feature</b>             | Fraser Camp  |
| <b>Location and Cause</b>  | leak from fuel source for locomotive train - over 6 M of track inside Canada border - started in Alaska, USA |
| <b>Latitude</b>            | 59.716667  |
| <b>Longitude</b>           | -135.066667  |
| <b>Incident Date</b>       | 6/8/1990   |
| <b>Lead Agency</b>         | Environment Canada - Environmental Protection Service  |
| <b>Other Agency</b>        |  |
| <b>Company(s)</b>          | White Pass & Yukon Route   |
| <b>Amount</b>              | 76   |
| <b>Units</b>               | Litres   |
| <b>Quantity</b>            | Estimate   |
| <b>Release Description</b> | Leaked   |
| <b>Additional Quantit</b>  |  |
| <b>Concentration</b>       |  |
| <b>Concentration Unit</b>  |  |
| <b>Phase</b>               | Liquid   |
| <b>Major Contaminant</b>   | Diesel   |
| <b>2nd Contaminant</b>     |  |
| <b>3rd Contaminant</b>     |  |
| <b>4th Contaminant</b>     |  |
| <b>Outcome</b>             | no recovery was attempted as fuel escaped into railbed ballast over 6 M of track                             |

Environment  
CanadaEnvironnement  
Canada

**Enforcement and Emergencies Section**  
 91782 Alaska Highway, Whitehorse, YT Y1A 5B7  
 PH: 867.667.3400 FAX: 867.667.7962

**Spill Report Information**

|                             |  |
|-----------------------------|--|
| <b>Spill #</b>              | 9423   |
| <b>Jurisdiction</b>         | Yukon  |
| <b>Community</b>            |  |
| <b>Address</b>              |  |
| <b>Highway</b>              | Klondike Highway   |
| <b>Milepost</b>             |  |
| <b>Feature</b>              | Fraser   |
| <b>Location and Cause</b>   | YTG Highway Maintenance Camp - discharge of contaminated water and sludge from garage sump - spills at refueling area                          |
| <b>Latitude</b>             | 59.71635842  |
| <b>Longitude</b>            | -135.04431478  |
| <b>Incident Date</b>        | 3/10/1994  |
| <b>Lead Agency</b>          | Provincial / Territorial - other   |
| <b>Other Agency</b>         |  |
| <b>Company(s)</b>           | YTG Highways   |
| <b>Amount</b>               |  |
| <b>Units</b>                |  |
| <b>Quantity</b>             | Unknown  |
| <b>Release Description</b>  | Chronic Discharge  |
| <b>Additional Quantitit</b> |  |
| <b>Concentration</b>        |  |
| <b>Concentration Unit</b>   |  |
| <b>Phase</b>                | Liquid   |
| <b>Major Contaminant</b>    | Hydrocarbons   |
| <b>2nd Contaminant</b>      |  |
| <b>3rd Contaminant</b>      |  |
| <b>4th Contaminant</b>      |  |
| <b>Outcome</b>              | contaminated water and sludge being dumped outside on ground - ground around fueling station contaminated - runoff into creek - advised BC MOE |



**Photo 0111:** 1500 Maintenance Garage with access to Water Equipment Room



**Photo 0112:** 1500 Hydroelectric Generating and Penstock Station



**Photo 0484:** 1500 Water Storage Tanks



**Photo 0486:** 1500 Filter System, 1 Micron Filter (left) and 10 Micron Filter (right)



**Photo 0485:** 1500 LMI Chlorinator



**Photo 0109:** 1500 Jet Pump and Backup Water Reservoir



**Photo 0489:** 1500 Pressure Tank



**Photo 0487:** 1500 Penstock Feed